



# Certificate of Conformity

## Certification Body:



ABN: 81 663 250 815  
JAS-ANZ Accreditation  
No. Z4450210AK  
PO Box 273,  
Palmwoods Qld 4555  
Australia  
P: +61 7 5445 2199  
[www.cmicert.com.au](http://www.cmicert.com.au)  
[office@cmicert.com.au](mailto:office@cmicert.com.au)

## Certificate Holder:



Askin Pty Ltd  
ABN: 13 156 186 033  
Level 3, Suite 3.01, 150  
Albert Road, South  
Melbourne VIC 3205  
Australia  
[www.askin.net.au](http://www.askin.net.au)

Certificate number: CM40337

### THIS IS TO CERTIFY THAT

## ASKIN EPS-FR Internal Walls & Ceilings Panel

### Type and/or use of product:

ASKIN EPS-FR Internal Walls & Ceilings panels are intended for use as interior walling & ceiling and cold room applications.

### Description of product:

The ASKIN EPS-FR Internal Walls & Ceilings panels comprise of SL Grade EPS core adhered between two steel facers made from a minimum thickness of 0.6mm G300 Colorbond. Refer to A2 for further details.

### COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

### BCA 2022 (Amdt. 2)

	Volume One	Volume Two
<b>Performance Requirement(s):</b>	B1P1(b)(iii) Structural reliability	Not Applicable
<b>Deemed-to-Satisfy Provision(s):</b>	C2D11(1)(b) Fire hazard properties - Refer A3	Not Applicable
<b>State or territory variation(s):</b>	Not Applicable	Not Applicable

### SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B

### Limitations and conditions:

- Construction shall be in strict accordance with the Installation Requirement detailed in the [Product Specification Sheet - Internal Walls & Ceilings EPS-FR Panel; Dated 22-01-2026](#) and either;
  - [ASKIN Interiors Panel Standard Details; Dated 19/9/2022](#); or
  - [ASKIN Interiors Cold Storage Standard Details; Dated 06/10/2022](#).
- This product has not been tested to AS 1530.1-1994 (R2016) and cannot be considered a non-combustible product.
- The ASKIN EPS-FR Panels must be fixed to a structurally adequate external wall frame in accordance with the appropriate span tables in section A3. The structural support members are designed and engineered separately as per project requirements by building designers and engineers.
- This certificate is limited to the details within this certificate including the above compliance elements, product description, purpose or use.
- Other than the items and information listed, the remainder of the information contained in the product's literature is outside the scope of this certification.
- The use of the certified product/system is subject to these Limitations and Conditions and must be read in conjunction with the Scope of Certification below.

### Building classification/s:

Classes 2,3,4,5,6,7,8 & 9

**Scope of certification:** The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website [www.abcb.gov.au](http://www.abcb.gov.au). This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the Certificate Holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Glen Gugliotti – CMI

Don Grehan – Unrestricted Building Certifier

Date of issue: 30/01/2026

Date of expiry: 30/01/2029





# Certificate of Conformity

Only criteria as identified within this Certificate of Conformity can be used for CodeMark certification claims. Where other claims are made in a client's Installation Manual, Website or other documents that are outside the criteria on this Certificate of Conformity, such criteria cannot be used or claimed to meet the requirements of this CodeMark certification.

The NCC defines a Performance Solution as one that complies with the Performance Requirements by means other than a Deemed-to-Satisfy Solution. A Building Solution that relies on a CodeMark Certificate of Conformity that certifies a product against the Performance Requirements cannot be considered as Deemed-to-Satisfy Solution.

This Certificate of Conformity may only relate to a part of a Performance Solution. In these circumstances other evidence of suitability is needed to demonstrate that the relevant Performance Requirements have been met. The relevant provisions of the Governing Requirements in Part A of the NCC will also need to be satisfied.

This Certificate of Conformity is issued based on the evidence of compliance as detailed herein. Any deviation from the specifications contained in this Certificate of Conformity is outside of this document's scope and the installation of the certified product will not be covered by this Certificate of Conformity.

**Disclaimer:** The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

When using the CodeMark logo in relation to or on the product/system, the Certificate Holder makes a declaration of compliance with the Scope of Certification and confirms that the product is identical to the product certified herein. In issuing this Certificate of Conformity, CMI Certification Pty Ltd (CMI) has relied on the experience and expertise of external bodies (laboratories and technical experts).

Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.

## APPENDIX A – PRODUCT TECHNICAL DATA

### A1 Type and intended use of product

As per page 1.

### A2 Description of product

The ASKIN EPS-FR Internal Walls & Ceilings panel has a minimum 0.6mm Colorbond G300 solid steel facers with a SL Grade EPS core material adhered to the steel facers with a 2-part polyurethane adhesive and come in the following thicknesses:

Thickness	Core Density
50, 75, 100, 125, 150, 175, 200, 250mm	13.5 kg/m <sup>3</sup>

### A3 Product specification

**Structural reliability** In order to maintain compliance with structure, the Span Tables located in the following Product Specification Sheet which have been certified by a licensed Professional Engineer must be referred to.

Document Name	Version
<a href="#">Product Specification Sheet - Internal Walls &amp; Ceilings EPS-FR Panel; Dated 22-01-2026</a>	January 2026

#### Group Number Classifications

- Group 1 – 150mm or less panel thickness** Smoke Growth Rate Index (**SMOGRA<sub>RC</sub>**) < 100
- Insulating sandwich panel, nominal thickness 150 mm or less
  - Panel to panel corner junctions require aluminium angles fixed to the steel skins at not more than 300mm centres, with aluminium rivets.

*Source: BRANZ; Certificate No. 373 Issue 2 Dated 23/02/2021.*

- Group 1 – 250mm or less panel thickness** Smoke Growth Rate Index (**SMOGRA<sub>RC</sub>**) < 100
- Insulating sandwich panel, nominal thickness 250 mm or less
  - Panel to panel junctions require steel angles fixed to the steel skins at not more than 300 mm centres, with steel rivets.
  - Ceiling panel to panels joins require a steel (stitch) rivet connecting the metal skins at not more than 1200 mm centres

*Source: BRANZ; Certificate No. 374 Issue 2 Dated 23/02/2021.*

- Group 2 – 250mm or less panel thickness** Smoke Growth Rate Index (**SMOGRA<sub>RC</sub>**) < 100
- Insulating sandwich panel, nominal thickness 250 mm or less.
  - Panel to panel junctions require steel angles fixed to the steel skins at not more than 300 mm centres, with steel rivets

*Source: BRANZ; Certificate No. 372 Issue 2 Dated 23/02/2021.*

**Fire Properties** AS/NZS 1530.3-1999 Methods for Fire Tests on Building Materials, Components and Structures Part 3: Simultaneous Determination of Ignitability, Flame Propagation, Heat Release and Smoke Release Indices for ASKIN EPS-FR External Wall & Facades Panel.

Ignitability Index	0	Range 0-20
Spread of Flame Index	0	Range 0-10
Heat Evolved Index	0	Range 0-10
Smoke Index	2	Range 0-10

*Source: Ignis Labs Pty Ltd; Report No. IGNL-6270-03-01 I01 R00; ASKIN product Evaluation – EPS Panels 50mm-300mm; Issued 23/11/2022.*

#### A4 Manufacturer and manufacturing plant(s)

This field is optional. Contact the Certificate Holder for details.

#### A5 Installation requirements

Construction shall be in strict accordance with the Installation Requirement detailed in the [Product Specification Sheet - Internal Walls & Ceilings EPS-FR Panel; Dated 22-01-2026](#) and either;

- [ASKIN Interiors Panel Standard Details; Dated 19/9/2022](#); or
- [ASKIN Interiors Cold Storage Standard Details; Dated 06/10/2022](#).

#### A6 Other relevant technical data

**Thermal Properties** The Declared Material R-values of ASKIN EPS (SL) expanded polystyrene insulated core panel have been determined in accordance with AS/NZS 4859.1:2018 and based off test reports for the 50mm & 250mm panel thicknesses.

Declared Material R-Value [(m <sup>2</sup> .K)/W]									
EPS (SL)	Thickness (mm)	50	75	100	125	150	175	200	250
Mean Temp(°C)	0°C	1.30	1.95	2.60	3.25	3.95	4.60	5.25	6.55
	15°C	1.20	1.80	2.40	3.00	3.65	4.25	4.85	6.05
	23°C	1.15	1.75	2.35	2.90	3.50	4.10	4.70	5.85

Calculations of Total R-value of ASKIN EPS-FR panels for Internal Wall construction performed in accordance with AS/NZS 4859.1:2018 are provided below. In all cases the construction is assumed to consist of the panel.

Australia									
Total R-Value [(m <sup>2</sup> .K)/W] (Summer/Winter) & System U-Value [W/(m <sup>2</sup> .K)] (Summer/Winter)									
EPS-FR (SL)	Thickness (mm)	50	75	100	125	150	175	200	250
Internal Wall	R <sub>(Sum.)</sub>	1.4	2.0	2.5	3.1	3.7	4.3	4.8	6.0
	U <sub>(Sum.)</sub>	0.72	0.51	0.40	0.32	0.27	0.23	0.21	0.17
	R <sub>(Wint.)</sub>	1.4	2.1	2.7	3.3	3.9	4.5	5.1	6.3
	U <sub>(Wint.)</sub>	0.39	0.48	0.38	0.31	0.26	0.22	0.20	0.16

*Source: Acronem Consulting Australia Pty Ltd; Thermal Performance of ASKIN EPS Core Panels letter Dated 15/09/2021.*

**Acoustic Performance**

The 75mm ASKIN EPS-FR Panels have been tested in accordance with AS 1191-2002 and assessed against AS/NZS ISO 717.1: 2004 by Acoustic Laboratories Australia Pty Ltd and achieve the following acoustic value.

Panel Thickness (mm)	R <sub>w</sub>	R <sub>w</sub> + C <sub>tr</sub>	R <sub>w</sub> (C, C <sub>tr</sub> )
Askin EPS-FR panel 75mm	25	20	25 (-4, -5)

*Source: Acoustic Laboratories Australia Pty Ltd; Report No.: ALA 09-080-1, Determination of the Airborne Sound Insulation of 75mm ECONOTILT™; Dated 25/03/2009*

## APPENDIX B – EVALUATION STATEMENTS

### B1 Evaluation methods

1. Fire Safety Provisions A5G3(1)(d)&(e). A report issued by an Accredited Testing Laboratory & a certificate or report from a professional engineer or other appropriately qualified person.
2. Structural Resistance Provisions A5G3(1)(e). A report from a professional engineer or other appropriately qualified person.

### B2 Reports

1. PENDYALA CONSULTING Pty Ltd; PC JOB NO. 22164; ASKIN EPS WALL PANELS. – Certification of Structural Competence; Dated 21/09/2022. This report contributes towards the compliance with B1P1(b)(iii).
2. Ignis Labs Pty Ltd; NATA Accreditation No. 20534; Report No. IGNL-6270-03-01 I01 R00; ASKIN product Evaluation – EPS Panels 50mm-300mm; Dated 23/11/2022. This report confirms compliance with C2D11(1)(b).
3. BRANZ; IANZ Accreditation No. 37; Test Report No. FAR 2489 ISSUE 3; FIRE ASSESSMENT REPORT; Dated 23/02/2021. This report confirms compliance with C2D11(1)(b).
4. BRANZ; IANZ Accreditation No. 37; Certificate No. 372 Issue 2; Fire Test Certificate AS ISO 9705; Dated 23/02/2021. These test reports document the ISO 9705 test results for compliance with C2D11(1)(b).
5. BRANZ; IANZ Accreditation No. 37; Certificate No. 373 Issue 2; Fire Test Certificate AS ISO 9705; Dated 23/02/2021. These test reports document the ISO 9705 test results for compliance with C2D11(1)(b).
6. BRANZ; IANZ Accreditation No. 37; Certificate No. 374 Issue 2; Fire Test Certificate AS ISO 9705; Dated 23/02/2021. These test reports document the ISO 9705 test results for compliance with C2D11(1)(b).
7. Acronem Consulting Australia Pty Ltd; Thermal Performance of ASKIN EPS Core Panels – Roofing, External Wall & Internal Wall Applications Letter; Dated 15/09/2021. This report provides the Thermal calculation details listed in A6.
8. Acoustic Laboratories Australia Pty Ltd; Report No.: ALA 09-080-1, Determination of the Airborne Sound Insulation of 75mm ECONOTILT™; Dated 25/03/2009. This report provides the Acoustic calculation details listed in A6.

The Certificate Holder has chosen not to make the above evidence of compliance publicly available, due to the documents being considered commercial in confidence.