



Certificate of Conformity

THIS CERTIFICATE IS GRANTED TO

BuildTuff Pty Ltd

11B/56 Lavarack Avenue, Eagle Farm, Queensland 4009 Australia

ABN: 650 818 885

W: <https://buildtuff.com.au>

T: +61 7 3184 4000

E: info@buildtuff.com

Subject to the following conditions and limitations:

1. The Approved Certifier grants the right to use or arrange the use of the WaterMark as shown in the top left corner only in respect of the Products described and detailed on the Product Schedule following which are produced by the Approved User and which comply with the appropriate Applicable Specification referenced below and as amended from time to time. The Licence is granted subject to the rules governing the use of the WaterMark and the terms and conditions for certification. The WaterMark Licensee covenants to comply with all the Rules, technical reference documents and terms and conditions of the WaterMark Certification Scheme.
2. The Certified products must be installed in accordance with the current version of the Plumbing Code of Australia.
3. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.
4. Information contained herein or related hereto is intended only for evaluation by technically skilled persons, with any use thereof to be at their independent discretion and risk. Such information is believed to be reliable, but CMI Certification Pty Ltd (CMI) shall have no responsibility or liability for results obtained or damages resulting from such use. CMI grants no license under, and shall have no responsibility or liability for infringement of, any patent or other proprietary right. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate holder.

Talissa Ireland

CMI Certification Pty Ltd

PO Box 273, Palmwoods, Qld 4555, Australia

ABN: 81 663 250 815

T: + 61 7 5445 2199

W: <https://cmicert.com.au>

E: office@cmicert.com.au



080115	05/06/2026	05/06/2026	05/06/2031	WMTS-476:2016 Heated Water Systems – Leak protection device
--------	------------	------------	------------	---

CERTIFICATE NUMBER	INITIAL CERTIFICATION DATE	CURRENT CERTIFICATION DATE	CERTIFICATION EXPIRY DATE	APPLICABLE STANDARD/SPECIFICATION
--------------------	----------------------------	----------------------------	---------------------------	-----------------------------------

This Certificate is issued by a JASANZ accredited certification body. The Scheme Owner, Administering Body and Accreditation Body do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The Scheme Owner disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate.

The WaterMark is a registered certification trademark of the Scheme Owner (ABN 74 599 608 295). The rules of the WaterMark Certification Scheme are available from the ABCB website www.abcb.gov.au





Schedule To BuildTuff Pty Ltd



APPLICABLE
STANDARD/SPECIFICATION

WMTS-476:2016 Heated Water Systems – Leak protection device

Brand Name	Model Name	Model Identification	Product Description	Scope of Use	Lead Free* Yes/No**/Not Applicable	Date Endorsed
BUILDTUFF	Joey Valve	JV15	Electronic water leak-sensing automated shut-off device – 316 Stainless Steel - 15mm for internal installed hot water systems – 3V 2400mAh battery operation with optional external mains power supply.	Cold Water Only Operating Temperature: 0°C to 50°C Maximum Pressure: 1034kPa Use: Internally Installed Hot Water Systems	N/A	05/06/2026
BUILDTUFF	Joey Valve	JV20	Electronic water leak-sensing automated shut-off device – 316 Stainless Steel - 20mm for internal installed hot water systems – 3V 2400mAh battery operation with optional external mains power supply.	Operating Temperature: 0°C to 50°C Maximum Pressure: 1034kPa Use: Internally Installed Hot Water Systems	N/A	05/06/2026
BUILDTUFF	Joey Valve	JV25	Electronic water leak-sensing automated shut-off device – 316 Stainless Steel - 25mm for internal installed hot water systems – 3V 2400mAh battery operation with optional external mains power supply.	Operating Temperature: 0°C to 50°C Maximum Pressure: 1034kPa Use: Internally Installed Hot Water Systems	N/A	05/06/2026
BUILDTUFF	Hydro Valve	AT601HV15	Electronic water leak-sensing automated shut-off device – 316 Stainless Steel - 15mm for internal installed hot water systems - 2 x AA battery operation with optional external mains power supply.	Operating Temperature: 0°C to 50°C Maximum Pressure: 1034kPa Use: Internally Installed Hot Water Systems	N/A	05/06/2026
BUILDTUFF	Hydro Valve	AT601HV20	Electronic water leak-sensing automated shut-off device – 316 Stainless Steel - 20mm for internal installed hot water systems - 2 x AA battery operation with optional external mains power supply.	Operating Temperature: 0°C to 50°C Maximum Pressure: 1034kPa Use: Internally Installed Hot Water Systems	N/A	05/06/2026
BUILDTUFF	Hydro Valve	AT601HV25	Electronic water leak-sensing automated shut-off device – 316 Stainless Steel - 25mm for internal installed hot water systems - 2 x AA battery operation with optional external mains power supply.	Operating Temperature: 0°C to 50°C Maximum Pressure: 1034kPa Use: Internally Installed Hot Water Systems	N/A	05/06/2026

*Lead Free compliance in accordance with NCC 2025 - Volume Three – Plumbing Code of Australia - A5G4(2)(b)

End of Record