



Certificate of Conformity

Certification Body:



ABN: 81 663 250 815
JAS-ANZ Accreditation
No. Z4450210AK
PO Box 273,
Palmwoods Qld 4555
Australia
P: +61 7 5445 2199
www.cmicert.com.au
office@cmicert.com.au

Certificate Holder:



Creepy Crawly
Pest Control Pty Ltd.
ABN: 930 729 184 35
Head Office:
41 Wilkinson Street,
Toowoomba Qld 4350
Australia
P: 1800-CRE-EPY (814 199)
www.creepycrawly.com.au

Certificate number: CM40025

THIS IS TO CERTIFY THAT

TermiFilm™ Termite Management System

Type and/or use of product:

The TermiFilm™ Termite Management System is an under slab, perimeter and penetration system to deter concealed entry by subterranean Termites into a building.

Description of product:

The TermiFilm™ Termite Management System is a physical-chemical Termite Management System utilising a high resistance Polyethylene film containing Permethrin.

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2022

	Volume One	Volume Two
Performance Requirement(s):	Not Applicable	Not Applicable
Deemed-to-Satisfy Provision(s):	B1D4(i) Determination of structural resistance of materials and forms of construction – Termite Risk Management	H1D3(3) Termite Management Systems
State or territory variation(s):	NT, QLD, WA B1D4(i)	QLD H1D3(3)

SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B

Limitations and conditions:

1. Must be installed in accordance with the [TermiFilm™ Manual V8 Feb 2025](#) & [APVMA label 67062/60858](#).
2. Only to be installed by a licenced Pest Control Operator in accordance with relevant state and territory regulations.
3. Inspections must be undertaken annually in accordance to determine that no bridging or breaching of the termite management system has occurred.
4. Footings and Slabs must be constructed in accordance with the requirements of AS 2870-2011 or AS 3600:2009 - Concrete Structures including amendments.
5. A durable notice, installed in accordance with BCA Volume One 2022: B1D4(i)(ii), including NT variation, & Part 3.4.3 of the ABCB Housing Provisions, must be affixed in a prominent location(s) to the building.
6. 50 years established via Design life predictions in accordance with Section 5 of AS 3660.3:2014.
7. The use of the certified product/system is subject to these Limitations and Conditions and must be read in conjunction with the Scope of Certification below.

Building classification/s:

Class 1,2,3,4,5,6,7,8,9 & 10

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the Certificate Holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.


Richard Donarski - CMI


Don Grehan – Unrestricted Building Certifier

Date of issue: 23/04/2025

Date of expiry: 29/04/2028





Certificate of Conformity

Only criteria as identified within this Certificate of Conformity can be used for CodeMark certification claims. Where other claims are made in a client's Installation Manual, Website or other documents that are outside the criteria on this Certificate of Conformity, such criteria cannot be used or claimed to meet the requirements of this CodeMark certification.

The NCC defines a Performance Solution as one that complies with the Performance Requirements by means other than a Deemed-to-Satisfy Solution. A Building Solution that relies on a CodeMark Certificate of Conformity that certifies a product against the Performance Requirements cannot be considered as Deemed-to-Satisfy Solution.

This Certificate of Conformity may only relate to a part of a Performance Solution. In these circumstances other evidence of suitability is needed to demonstrate that the relevant Performance Requirements have been met. The relevant provisions of the Governing Requirements in Part A of the NCC will also need to be satisfied.

This Certificate of Conformity is issued based on the evidence of compliance as detailed herein. Any deviation from the specifications contained in this Certificate of Conformity is outside of this document's scope and the installation of the certified product will not be covered by this Certificate of Conformity.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

When using the CodeMark logo in relation to or on the product/system, the Certificate Holder makes a declaration of compliance with the Scope of Certification and confirms that the product is identical to the product certified herein. In issuing this Certificate of Conformity, CertMark International has relied on the experience and expertise of external bodies (laboratories and technical experts).

Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

As per page 1.

A2 Description of product

The TermiFilm™ Termite Management System consists of the following components:

- TermiFilm™ - Roll Sizes: 100m x 200mm, 100m x 250mm, 100m x 300mm, 50m x 300mm, 100m x 1m, 50m x 4m;
- 3M Performance Plus Duct Tape (for sealing overlaps in Termite Blanket application);
- TermiFilm™ Sealant (Termite resistant flexible) 410g (to seal blanket on to substrates and overlaps of Termite Blanket);
- TermiFilm™ Epoxy Kit (Termite resistant - to seal blanket on to substrates and overlaps of Termite Blanket);
- TermiFilm™ High Tact Multi-Purpose Adhesive (for sealing overlaps and adhesion to substrates, particularly retainer walls to hold in place);
- Panduit Cable Ties for collar installations;
- TermiFilm™ Grip Strip for sill till adhesion for doorway installations.

A3 Product specification

Active Constituent 10g/kg Permethrin 25:75.
Group 3A Insecticide.

A4 Manufacturer and manufacturing plant(s)

Creepy Crawly Pest Control Pty Ltd
41 Wilkinson Street,
Toowoomba QLD 4350.

A5 Installation requirements

1. Must be installed in accordance with the [TermiFilm™ Manual V8 Feb 2025](#) & [APVMA label 67062/60858](#).
2. The TermiFilm™ Termite Management System is to be installed by authorised operators trained and licensed by Creepy Crawly Pest Control Pty Ltd.

A6 Other relevant technical data

No other relevant technical data.

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

1. Termite Risk Management – A5.2(1)(e). Reports from Appropriately Qualified Persons.

B2 Reports

1. Technical opinion Australian Timber & Pest Research Pty Ltd (ATPR) the compliance of Termifilm in accordance with the requirements of AS 3660.1:2014 and AS 3660.3:2014 and the relevant sections of the 2019 National Construction Code; Dated 02/06/2020. Provides Compliance with B1D4(i) and H1D3(3).
2. CSIRO; (NATA 165), Entomology Termite Group Report No 2005/14; Evaluation of permethrin-treated Termifilm; Dated May 2005. Provides Compliance with B1D4(i) and H1D3(3).
3. CSIRO; (NATA 165), Entomology Termite Group Report No 2005/12; Evaluation of permethrin-treated Termifilm; Dated April 2005. Provides Compliance with B1D4(i) and H1D3(3).
4. APVMA Label 67062/60858 Termifilm™ Termite Exclusion System. Provides Compliance with B1D4(i) and H1D3(3).

The Certificate Holder has chosen not to make the above evidence of compliance publicly available, due to the documents being considered commercial in confidence.