Certificate of Conformity

BCA 2022 – Refer to page 9 onwards

Certificate number: CM40301 Rev3

THIS IS TO CERTIFY THAT

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture

Type and/or use of product:

External cladding on residential and commercial facades.

Description of product:

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture are fibre-cement wall cladding boards featuring shiplap joints that can be installed in a horizontal or vertical orientation.

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S) **BCA 2025**

	Volume One		Volume Two	
Performance Requirement(s):	B1P1(3)(a)&(c)	Structural reliability – Permanent and wind actions subject to *Limitation and Condition No. 2 & 7.*	H1P1(3)(a)&(c)	Structural reliability and resistance – Permanent and wind actions subject to *Limitation and Condition No. 2 & 7.*
	F1P1	Water Management - Weatherproofing of external walls subject to *Limitation and Condition No. 3*.	H2P2	Weatherproofing – External walls subject to *Limitation and Condition No. 3*.
Deemed-to-Satisfy Provision(s):	C2D10(6)(d)	Non-combustible building elements – Fibre-reinforced cement sheeting – Panel Only	H1D7(4)(b)	Wall cladding – Fibre cement
	F8D3	Condensation management – External wall construction subject to *Limitation and Condition No. 5*	H3D2(1)(d)	Non-combustible building elements – Fibre-reinforced cement sheeting – Panel Only
	G5D3	Construction in bushfire prone areas – BAL Low–40 subject to *limitation & condition 8*	H4D9	Condensation management – External wall construction subject to *Limitation and Condition No. 5*
			H7D4	Construction in bushfire prone areas – BAL Low–40 subject to *limitation & condition 8*
State or territory variation(s):	G5D3 (NSW)		H7D4 (NSW, QLD & TAS)	

SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B

Limitations and conditions:

1. Stria™ Cladding Fine Texture must be installed in accordance with the appropriate guide based on the orientation.
   a. Horizontal application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026.
   b. Vertical application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026.
2. Compliance with B1P1(3)(c) & H1P1(3)(c) excludes resistance to impact loading from windborne debris.

Building classification/s:

Class 1,2,3,4,5,6,7,8,9 & 10

Certification Body:

CMI CERTIFICATION
ABN: 81 663 250 815
JASANZ Accreditation No. Z4450210AK
PO Box 273,
Palmwoods Qld 4555
Australia
P: +61 7 5445 2199
www.cmicert.com.au
office@cmicert.com.au

Certificate Holder:

JamesHardie
James Hardie Australia Pty Ltd
ABN: 12 084 635 558
10 Colquhoun St,
Rosehill NSW 2142
Australia
P: 13 11 03
www.jameshardie.com.au

Glen Gugliotti – CMI

Don Grehan – Unrestricted Building Certifier

Date of issue: 29/10/2026

Date of expiry: 28/10/2027

3. To satisfy F1P1 & H2P2 via verification requires the site specific evaluation of the relevant design against F1V1 and/or H2V1 to the satisfaction of the Appropriate Authority as defined by the NCC:
   a. has a risk score of 20 or less, when the sum of all risk factor scores are determined in accordance with Table F1V1a/H2V1a; and
   b. includes only windows that comply with AS 2047.

   Compliance with Weatherproofing is limited to the tested specimen, any deviations from this are subject to site specific design and approval by the regulatory authority.
4. In all installations the minimum clearance between the underside of panel and the adjoining ground surface level below must comply with the specifications in Part 7.5.7 of the ABCB Housing Provisions.
5. Compliance with Condensation Management requires external wall construction in accordance with the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026. Where a pliable building membrane or a sarking-type material is installed as a control layer it must comply with AS 4200.1:2017 must be installed in accordance with AS 4200.2:2017 and must achieve the vapour permeance specified in Table F8D3 or Table 10.8.1 to separate the wall cladding panels from any water sensitive materials. For Climate Zone 6, 7 & 8, Stria™ Cladding Smooth and Stria™ Cladding Fine Texture must be Cavity Fixed.
6. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture complies with H1D7(4)(b) as cladding that satisfies the following sections of Part 7.5 of the ABCB Housing Provisions:
   a. 7.5.3(a) for wall cladding boards.
7. The structural certification is limited to the cladding only and does not include the sub-structure. The structural support members are designed and engineered separately as per project requirements by building designers and engineers.
8. In order to maintain compliance with BAL Low – 40, it is the responsibility of the Building Designer to ensure compliance is achieved in accordance with AS 3959-2018. In order to comply with the NSW provisions of G5D3, a site-specific performance solution is to be prepared in line with the Planning for Bush Fire Protection 2019 guidance document.
9. This certificate is limited to the details within this certificate including the above compliance elements, product description, purpose or use. Other than the items and information listed, the remainder of the information contained in the product's literature is outside the scope of this certification.
10. The use of the certified product/system is subject to these Limitations and Conditions and must be read in conjunction with the Scope of Certification below

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the Certificate Holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Only criteria as identified within this Certificate of Conformity can be used for CodeMark certification claims. Where other claims are made in a client's Installation Manual, Website or other documents that are outside the criteria on this Certificate of Conformity, such criteria cannot be used or claimed to meet the requirements of this CodeMark certification.

The NCC defines a Performance Solution as one that complies with the Performance Requirements by means other than a Deemed-to-Satisfy Solution. A Building Solution that relies on a CodeMark Certificate of Conformity that certifies a product against the Performance Requirements cannot be considered as Deemed-to-Satisfy Solution.

This Certificate of Conformity may only relate to a part of a Performance Solution. In these circumstances other evidence of suitability is needed to demonstrate that the relevant Performance Requirements have been met. The relevant provisions of the Governing Requirements in Part A of the NCC will also need to be satisfied.

This Certificate of Conformity is issued based on the evidence of compliance as detailed herein. Any deviation from the specifications contained in this Certificate of Conformity is outside of this document's scope and the installation of the certified product will not be covered by this Certificate of Conformity.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

Certificate of Conformity

When using the CodeMark logo in relation to or on the product/system, the Certificate Holder makes a declaration of compliance with the Scope of Certification and confirms that the product is identical to the product certified herein. In issuing this Certificate of Conformity, CMI Certification Pty Ltd (CMI) has relied on the experience and expertise of external bodies (laboratories and technical experts).

Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

As per page 1.

A2 Description of product

Cladding

Stria™ Cladding Smooth

Note: All dimensions and masses are approximate and subject to manufacturing tolerances

Description		Product Code	Length (mm)	Width (mm)	Weight (kg/m²)*
Pre-sealed 14mm thick shiplap boards with deep and wide grooves to create strong, clean lines	**Stria™ Cladding 325 Smooth**	404063	4200	325	19.1
		405504	3000	325	19.1
	Stria™ Cladding 405 Smooth	404413	4200	405	19.4
		405505	3000	405	19.4

Stria™ Cladding Fine Texture

Note: All dimensions and masses are approximate and subject to manufacturing tolerances

Description	Product Code	Length (mm)	Width (mm)	Weight (kg/m²)*
Pre-sealed 14mm thick shiplap boards with deep 'V' grooves to create strong, clean lines	405570	4200	325	19.1
	405571	3000	325	19.1

* Includes the product weight only, taking into account effective coverage. This excludes fasteners, sealants and other accessories.

Components:

Hardie™ Cavity Batten – Fibre cement trim used to fix external cladding to steel or timber frame
Hardie™ Weather Barrier – Water barrier and vapour permeable membrane compliant to AS 4200.1:2017.
Hardie™ Joint Sealant – General purpose polyurethane exterior grade sealant.
Hardie™ 18mm PVC Cavity Vent Strip – A perforated PVC extrusion used at the bottom of walls behind cladding.
Hardie™ 35mm PVC Cavity Vent Strip – A 3000mm long perforated PVC extrusion installed at the base of the cladding wall system to provide drainage, ventilation and vermin proofing.
Stria™ Stop – For use with Stria™ Cladding behind boards at vertical joints
Hardie™ 14mm Aluminium External Box Corner – A ready to paint aluminium extrusion. 3000mm long
Hardie™ 14mm Aluminium External Slimline Corner – A sleek external corner with a sharp, minimal edge. It holds the panels tight with just 3.5mm of coverage
Hardie™ 14mm Aluminium Internal Corner – A ready to paint aluminium extrusion. 3000mm long
Hardie™ 75mm Corner Flashing – Manufactured using COLORBOND® steel, used behind cladding at internal and external corners. 75 x 75mm
Hardie™ Trimline Flashing – To be used at horizontal joints (vertical cladding) or vertical butt joints (Horizontal cladding).
Hardie™ Edge Base Trim – Powder coated aluminium extrusion used at slab edges.
Hardie™ Edge Base Trim Jointer – Powder coated aluminium extrusion used with Hardie™ Edge Base Trim.
Hardie™ Edge Internal Corner – Powder coated aluminium extrusion used with Hardie™ Edge Base Trim at internal corner junctions.
Hardie™ Edge External Corner – Powder coated aluminium extrusion used with Hardie™ Edge Base Trim at external corner junctions.
Hardie™ Foam Back Sealing Tape – Installed under sheet vertical joints to improve water tightness. 50mm wide 25mtr long roll.
Hardie™ Break Thermal Strip - A hard, dual layer density self-adhesive strip, for quick installation. The thermal strip is installed directly over a vapour permeable membrane and framing members.

A3 Product specification

Structural reliability and resistance [B1P1(3)(a) & (c) & H1P1(3)(a)&(c)]

In order to maintain compliance with structure, Stria™ Cladding Smooth and Stria™ Cladding Fine Texture must be installed with fixing details as specified in the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026 which specifies the Framing and Fastener Requirements in Table 2 and Table 3 respectively and Batten requirements are specified in Table 4

Source: *David Beneke Consulting Report No. 2025-04-LO-15 dated 07/02/2025 & Report No. 2024-05-LO-75 dated 12/03/2024.*

Water Management & Weatherproofing [F1P1 & H2P2]

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture – Cavity Fixed Horizontal or Vertical

The weatherproofing performance of the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Cavity Fixed system installed in applications where an external wall;

1. has a risk score of 20 or less, when the sum of all risk factor scores are determined in accordance with Table F1V1a/H2V1a; and
2. includes only windows that comply with AS 2047

has been confirmed via testing to the Verification Method F1V1/H2V1 and is limited to the tested specimen, deviations from this specimen is subject to site specific design and approval by the regulatory authority.

Serviceable Limit State Pressure:	**±1.515 kPa**

Where a F8D3 and Section 10.8.1 of the ABCB housing provisions require a drained and ventilated cavity, it must;

a. be located between the cladding and the external side of the primary insulation layer, or the outermost control layer; and
b. be constructed from cavity battens, spacers or the like where applicable with a depth of at least 12 mm; and
c. be unobstructed by any control layer; and
d. be drained to the exterior, including where cavities are vertically compartmentalised in a multi- storey building; and
e. have openings with a free area of no less than 1,000 mm²/m of wall provided at
    i. the base and top of the cavity; or
    ii. each storey or level to where the cavity is closed.

The drained and ventilated cavity requirement is mandatory for buildings in Climate Zones 6, 7 and 8.

Source: *James Hardie Research Pty Ltd Test Report No. TS003-13, Weathertightness – Horizontal dated 04/12/2013, Test Report No. TS022-23, Weathertightness – Vertical dated 06/12/2023 and James Hardie Research Pty Ltd – Advice Note dated 27/10/2022, and James Hardie Research Pty Ltd – Compliance Notification Reference No. JHR/DC20240807 dated 07/08/2024 and Letter of Opinion from James Hardie Research Pty Ltd dated 20/07/2026.*

Water Management & Weatherproofing [F1P1 & H2P2]	**Stria™ Cladding Smooth and Stria™ Cladding Fine Texture – Direct Fixed** The weatherproofing performance of the Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Direct Fixed system installed in applications where an external wall; 1. has a risk score of 20 or less, when the sum of all risk factor scores are determined in accordance with Table F1V1a/H2V1a; and 2. includes only windows that comply with AS 2047 has been confirmed via testing to the Verification Method F1V1/H2V1 and is limited to the tested specimen, deviations from this specimen is subject to site specific design and approval by the regulatory authority. **Serviceable Limit State Pressure: ±1.515 kPa** NOTE: Direct fix is not suitable in Climate Zone 6,7 & 8 where a drained and ventilated cavity is required as per Table F8D3 and Table 10.8.1 ***Source:*** *Test Report No. TS011-18, Weathertightness –Direct Fix dated 01/05/2018 and James Hardie Research Pty Ltd – Advice Note dated 27/10/2022, and James Hardie Research Pty Ltd – Compliance Notification Reference No. JHR/DC20240807 dated 07/08/2024 and Letter of Opinion from James Hardie Research Pty Ltd dated 20/07/2026.*
Condensation Management [F8D3 & H4D9]	Compliance with Condensation Management requires external wall construction in accordance with the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026. Where a pliable building membrane or a sarking-type material is installed as a control layer it must comply with AS 4200.1:2017 must be installed in accordance with AS 4200.2:2017 and must achieve the vapour permeance specified in Table F8D3 or Table 10.8.1 to separate the wall cladding panels from any water sensitive materials. For Climate Zone 6, 7 & 8, Stria™ Cladding Smooth and Stria™ Cladding Fine Texture must be Cavity Fixed. ***Source:*** *Letter of Opinion from James Hardie Research Pty Ltd dated 20/07/2026 and Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guides; Horizontal – September 2026 and Vertical – September 2026.*
Bushfire [G5D3 & H7D4]	An assessment of Stria™ Cladding Smooth and Stria™ Cladding Fine Texture has been completed by Ignis Labs Pty Ltd and is considered to be consistent with, and to satisfy, the requirements of AS 3959:2018 for BAL Low – 40 areas, subject to the installation in accordance with the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026. The PVC Cavity Vent Strip used within Stria™ Cladding Smooth and Stria™ Cladding Fine Texture (305555 Hardie™ 18mm PVC Cavity Vent Strip 3000mm & 306253 Hardie™ 35mm PVC Cavity Vent Strip 3000mm) have been assessed and are considered suitable for use and satisfy the requirements of AS 3959:2018 and maintain compliance with BAL Low – 40 areas. All joints in the external surface material of the wall shall be covered, sealed, overlapped, backed or butt-jointed to prevent gaps greater than 3 mm ***Source:*** *Ignis Labs Pty Ltd Report No. IGNE-260152-99-01R-I04R00 Bushfire Assessment Report issued 24/08/2026.*
Non-combustible [C2D10(6)(d) & H3D2(1)(d)]	Stria™ Cladding Smooth and Stria™ Cladding Fine Texture panels are suitable where non-combustible materials are required in accordance with C2D10(6)(d) and H3D2(1)(d) of the Building Code of Australia as fibre-reinforced cement sheeting that complies with AS/NZS 2908.2:2000. ***Source:*** *James Hardie Research Pty Ltd Test Report Number TS022-10; Testing in accordance with AS/NZS 2908.2:2000 Products Part 2: Flat Sheets; Dated 10/02/2021.*
Wall cladding – Fibre cement [H1D7(4)(b)]	The basic composition is Portland cement, ground sand, cellulose fibre and water. James Hardie building products are manufactured to Australian/New Zealand Standard AS/NZS 2908.2:2000 'Cellulose-cement products-Flat sheet'. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture panels are classified Type A, Category 3 in accordance with AS/NZS 2908.2:2000. ***Source:*** *James Hardie Research Pty Ltd Test Report Number TS022-10; Testing in accordance with AS/NZS 2908.2:2000 Products Part 2: Flat Sheets; Dated 10/02/2021.*

A4 Manufacturer and manufacturing plant(s)

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture weatherboards are manufactured in Australia by James Hardie Australia Pty Ltd. Contact Certificate Holder for details.

A5 Installation requirements

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture must only to be installed in accordance with either;

a) Horizontal application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026.
b) Vertical application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026.

A6 Other relevant technical data

When installing Stria™ Cladding Smooth and Stria™ Cladding Fine Texture in combination with other CodeMark certified Hardie™ Cladding Products, refer to the Hardie™ Architectural Collection Joints and Junctions Application Guide on James Hardie's website. Refer JHR Advisory Note 080920230905 - HAC Opinion Based Upon Tested Prototype Compliance Note dated 14/09/2023.

Resistance to fire	Testing has been conducted by CSIRO on the Hardie™ Cladding materials in accordance with AS/NZS 3837:1998 and are classified as conforming to Group 1 material. (Average Specific Extinction Area 9.3m^2/Kg). For further details, contact the Certificate Holder. ***Source:*** *CSIRO Test Certificate No. 1149 dated 28/08/2008*

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

1. Ancillary Provisions A5G3(1)(e). Reports from a professional engineer.
2. Characteristic Type Testing A5G3(1)(d). Reports from Accredited Testing Laboratories.
3. Condensation Management Provisions A5G3(1)(d)&(f). Reports from Accredited Testing Laboratory and other forms of documentary evidence.
4. Fire Safety Provision A5G3(1)(d) & (e). Reports from Accredited Testing Laboratories and a professional engineer.
5. Structural Provision A5G3(1)(e). Reports from a professional engineer.
6. Weatherproofing Provisions A5G3(1)(d). Reports from Accredited Testing Laboratories.

B2 Reports

1. Compliance with B1P1(3)(a)&(c) and H1P1(3)(a)&(c) has been confirmed by the following reports:
    a. David Beneke Consulting; Report 2025-04-LO-15; Structural Compliance Certificate of James Hardie Stria Weatherboard External Cladding; Dated 07/02/2025.
    b. David Beneke Consulting Pty Ltd; Report No. 2024-05-LO-75; Certification of James Hardie Structural Castellated Battens – Revision 3; Dated 12/03/2024.
2. Compliance with G5D3 and H7D4 has been confirmed by the following reports:
    a. Ignis Labs Pty Ltd Report No. IGNE-260152-99-01R-I04R00; Bushfire Assessment Report; Dated 24/08/2026.
3. Compliance with C2D10(6)(d), H1D7(4)(b) and H3D2(1)(d) has been confirmed by the following reports:
    a. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Report TS022-10; Characteristic Type Tests required by AS/NZS 2908.2:2000; Dated 10/02/2021.
4. Compliance with F1P1 and H2P2 has been confirmed by the following reports:
    a. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Report Reference No. JHR/DC20240807 Compliance Notification – James Hardie Stria™ Cladding Fine Texture Interlocking Joint Similar to James Hardie Stria™ / Oblique™ Interlocking Joint; Dated 07/08/2024.
    b. James Hardie Research Pty Ltd, NATA Accreditation No. 14220; James Hardie Advice Note - Compliance Notification of Stria™ Horizontal and Vertical Fixing Installation (Direct to Frame, and Cavity Installation); Dated 27/10/2022.
    c. James Hardie Research Pty Ltd, NATA Accreditation No. 14220; Test Report Number TS003-13; Cavity Fix Weathertightness; Dated 04/12/2013.
    d. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Report Number TS011-18; Weathertightness compliance report; Dated 01/05/2018.
    e. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Report Number TS022-23; Weathertightness compliance report, Structural Castellated Batten Installation (Cavity Fix) – Clad with James Hardie™ Oblique Vertical Cladding System; Dated 06/12/2023
    f. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Letter of Opinion dated 20/07/2026.
5. Compliance with F8D3 and H4D9 has been confirmed by the following documentation:
    a. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Letter of Opinion dated 20/07/2026.
    b. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026.
    c. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026.

The Certificate Holder has chosen not to make the above evidence of compliance publicly available, due to the documents being considered commercial in confidence.

Certificate of Conformity

Certification Body:

CMI CERTIFICATION
ABN: 81 663 250 815
JASANZ Accreditation No. Z4450210AK
PO Box 273,
Palmwoods Qld 4555
Australia
P: +61 7 5445 2199
www.cmicert.com.au
office@cmicert.com.au

Certificate Holder:

James Hardie
Australia Pty Ltd
ABN: 12 084 635 558
10 Colquhoun St,
Rosehill NSW 2142
Australia
P: 13 11 03
www.jameshardie.com.au

Certificate number: CM40301 Rev3

THIS IS TO CERTIFY THAT

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture

Type and/or use of product:

External cladding on residential and commercial facades.

Description of product:

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture are fibre-cement wall cladding boards featuring shiplap joints that can be installed in a horizontal or vertical orientation.

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S) **BCA 2022 (Amdt. 2)**

	Volume One		Volume Two	
Performance Requirement(s):	B1P1(2)(a)&(c)	Structural reliability – Permanent and wind actions subject to *Limitation and Condition No. 2 & 7.*	H1P1(2)(a)&(c)	Structural reliability and resistance – Permanent and wind actions subject to *Limitation and Condition No. 2 & 7.*
	F3P1	Weatherproofing - External walls subject to *Limitation and Condition No. 3*.	H2P2	Weatherproofing – External walls subject to *Limitation and Condition No. 3*.
Deemed-to-Satisfy Provision(s):	C2D10(6)(d)	Non-combustible building elements – Fibre-reinforced cement sheeting – Panel Only	H1D7(4)(b)	Wall cladding – Fibre cement
	F8D3	Condensation management – External wall construction subject to *Limitation and Condition No. 5*	H3D2(1)(d)	Non-combustible building elements – Fibre-reinforced cement sheeting – Panel Only
	G5D3	Construction in bushfire prone areas – BAL Low-40 subject to *limitation & condition 8*	H4D9	Condensation management – External wall construction subject to *Limitation and Condition No. 5*
			H7D4	Construction in bushfire prone areas (BAL Low-40)
State or territory variation(s):	G5D3 (NSW)		H7D4 (NSW, QLD & TAS)	

SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B

Limitations and conditions:

1. Stria™ Cladding Fine Texture must be installed in accordance with the appropriate guide based on the orientation.
   a. Horizontal application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026.
   b. Vertical application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026.
2. Compliance with B1P1(2(c) & H1P1(2)(c) excludes resistance to impact loading from windborne debris.

Building classification/s:

Class 1,2,3,4,5,6,7,8,9 & 10

Glen Gugliotti – CMI

Don Grehan – Unrestricted Building Certifier

Date of issue: 29/10/2026

Date of expiry: 28/10/2027

3. To satisfy F3P1 & H2P2 via verification requires the site specific evaluation of the relevant design against F3V1 and/or H2V1 to the satisfaction of the Appropriate Authority as defined by the NCC:
    a. has a risk score of 20 or less, when the sum of all risk factor scores are determined in accordance with Table F3V1a/H2V1a; and
    b. is not subjected to an ultimate limit state wind pressure of more than 2.5kPa; and
    c. includes only windows that comply with AS 2047.

    Compliance with Weatherproofing is limited to the tested specimen, any deviations from this are subject to site specific design and approval by the regulatory authority.
4. In all installations the minimum clearance between the underside of panel and the adjoining ground surface level below must comply with the specifications in Part 7.5.7 of the ABCB Housing Provisions.
5. Compliance with Condensation Management requires external wall construction in accordance with the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026. Where a pliable building membrane or a sarking-type material is installed as a control layer it must comply with AS 4200.1:2017 must be installed in accordance with AS 4200.2:2017 and must achieve the vapour permeance specified in F8D3(2) or 10.8.1(2) to separate the wall cladding panels from any water sensitive materials.
6. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture complies with H1D7(4)(b) as cladding that satisfies the following sections of Part 7.5 of the ABCB Housing Provisions:
    a. 7.5.3(a) for wall cladding boards.
7. The structural certification is limited to the cladding only and does not include the sub-structure. The structural support members are designed and engineered separately as per project requirements by building designers and engineers.
8. In order to maintain compliance with BAL Low – 40, it is the responsibility of the Building Designer to ensure compliance is achieved in accordance with AS 3959-2018. In order to comply with the NSW provisions of G5D3, a site-specific performance solution is to be prepared in line with the Planning for Bush Fire Protection 2019 guidance document.
9. This certificate is limited to the details within this certificate including the above compliance elements, product description, purpose or use.
    Other than the items and information listed, the remainder of the information contained in the product's literature is outside the scope of this certification.
10. The use of the certified product/system is subject to these Limitations and Conditions and must be read in conjunction with the Scope of Certification below.

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the Certificate Holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Only criteria as identified within this Certificate of Conformity can be used for CodeMark certification claims. Where other claims are made in a client's Installation Manual, Website or other documents that are outside the criteria on this Certificate of Conformity, such criteria cannot be used or claimed to meet the requirements of this CodeMark certification.

The NCC defines a Performance Solution as one that complies with the Performance Requirements by means other than a Deemed-to-Satisfy Solution. A Building Solution that relies on a CodeMark Certificate of Conformity that certifies a product against the Performance Requirements cannot be considered as Deemed-to-Satisfy Solution.

This Certificate of Conformity may only relate to a part of a Performance Solution. In these circumstances other evidence of suitability is needed to demonstrate that the relevant Performance Requirements have been met. The relevant provisions of the Governing Requirements in Part A of the NCC will also need to be satisfied.

This Certificate of Conformity is issued based on the evidence of compliance as detailed herein. Any deviation from the specifications contained in this Certificate of Conformity is outside of this document's scope and the installation of the certified product will not be covered by this Certificate of Conformity.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

Certificate of Conformity

When using the CodeMark logo in relation to or on the product/system, the Certificate Holder makes a declaration of compliance with the Scope of Certification and confirms that the product is identical to the product certified herein. In issuing this Certificate of Conformity, CMI Certification Pty Ltd (CMI) has relied on the experience and expertise of external bodies (laboratories and technical experts).

Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

As per page 1.

A2 Description of product

Cladding

Stria™ Cladding Smooth

Note: All dimensions and masses are approximate and subject to manufacturing tolerances

Description		Product Code	Length (mm)	Width (mm)	Weight (kg/m²)*
Pre-sealed 14mm thick shiplap boards with deep and wide grooves to create strong, clean lines	**Stria™ Cladding 325 Smooth**	404063	4200	325	19.1
		405504	3000	325	19.1
	Stria™ Cladding 405 Smooth	404413	4200	405	19.4
		405505	3000	405	19.4

Stria™ Cladding Fine Texture

Note: All dimensions and masses are approximate and subject to manufacturing tolerances

Description	Product Code	Length (mm)	Width (mm)	Weight (kg/m²)*
Pre-sealed 14mm thick shiplap boards with deep 'V' grooves to create strong, clean lines	405570	4200	325	19.1
	405571	3000	325	19.1

* Includes the product weight only, taking into account effective coverage. This excludes fasteners, sealants and other accessories.

Components:

Hardie™ Cavity Batten – Fibre cement trim used to fix external cladding to steel or timber frame
Hardie™ Weather Barrier – Water barrier and vapour permeable membrane compliant to AS 4200.1:2017.
Hardie™ Joint Sealant – General purpose polyurethane exterior grade sealant.
Hardie™ 18mm PVC Cavity Vent Strip – A perforated PVC extrusion used at the bottom of walls behind cladding.
Hardie™ 35mm PVC Cavity Vent Strip – A 3000mm long perforated PVC extrusion installed at the base of the cladding wall system to provide drainage, ventilation and vermin proofing.
Stria™ Stop – For use with Stria™ Cladding behind boards at vertical joints
Hardie™ 14mm Aluminium External Box Corner – A ready to paint aluminium extrusion. 3000mm long
Hardie™ 14mm Aluminium External Slimline Corner – A sleek external corner with a sharp, minimal edge. It holds the panels tight with just 3.5mm of coverage
Hardie™ 14mm Aluminium Internal Corner – A ready to paint aluminium extrusion. 3000mm long
Hardie™ 75mm Corner Flashing – Manufactured using COLORBOND® steel, used behind cladding at internal and external corners. 75 x 75mm
Hardie™ Trimline Flashing – To be used at horizontal joints (vertical cladding) or vertical butt joints (Horizontal cladding).
Hardie™ Edge Base Trim – Powder coated aluminium extrusion used at slab edges.
Hardie™ Edge Base Trim Jointer – Powder coated aluminium extrusion used with Hardie™ Edge Base Trim.
Hardie™ Edge Internal Corner – Powder coated aluminium extrusion used with Hardie™ Edge Base Trim at internal corner junctions.
Hardie™ Edge External Corner – Powder coated aluminium extrusion used with Hardie™ Edge Base Trim at external corner junctions.
Hardie™ Foam Back Sealing Tape – Installed under sheet vertical joints to improve water tightness. 50mm wide 25mtr long roll.
Hardie™ Break Thermal Strip - A hard, dual layer density self-adhesive strip, for quick installation. The thermal strip is installed directly over a vapour permeable membrane and framing members.

A3 Product specification

Structural reliability and resistance [B1P1(2)(a) & (c) & H1P1(2)(a)&(c)]	In order to maintain compliance with structure, Stria™ Cladding Smooth and Stria™ Cladding Fine Texture must be installed with fixing details as specified in the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026 which specifies the Framing and Fastener Requirements in Table 2 and Table 3 respectively and Batten requirements are specified in Table 4 ***Source**: David Beneke Consulting Report No. 2025-04-LO-15 dated 07/02/2025 & Report No. 2024-05-LO-75 dated 12/03/2024.*
Weatherproofing [F3P1 & H2P2]	**Stria™ Cladding Smooth and Stria™ Cladding Fine Texture – Cavity Fixed Horizontal or Vertical** The weatherproofing performance of the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Cavity Fixed system installed in applications where an external wall; 1. has a risk score of 20 or less, when the sum of all risk factor scores are determined in accordance with Table F3V1a/H2V1a; and 2. is not subjected to an ultimate limit state wind pressure of more than 2.5kPa; and 3. includes only windows that comply with AS 2047 has been confirmed via testing to the Verification Method F3V1/H2V1 and is limited to the tested specimen, deviations from this specimen is subject to site specific design and approval by the regulatory authority. **Serviceable Limit State Pressure: ±1.515 kPa** ***Source:** James Hardie Research Pty Ltd Test Report No. TS003-13, Weathertightness – Horizontal dated 04/12/2013, Test Report No. TS022-23, Weathertightness – Vertical dated 06/12/2023 and James Hardie Research Pty Ltd – Advice Note dated 27/10/2022, and James Hardie Research Pty Ltd – Compliance Notification Reference No. JHR/DC20240807 dated 07/08/2024 and Letter of Opinion from James Hardie Research Pty Ltd dated 20/07/2026.*
Weatherproofing [F3P1 & H2P2]	**Stria™ Cladding Smooth and Stria™ Cladding Fine Texture – Direct Fixed** The weatherproofing performance of the Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Direct Fixed system installed in applications where an external wall; 1. has a risk score of 20 or less, when the sum of all risk factor scores are determined in accordance with Table F3V1a/H2V1a; and 2. is not subjected to an ultimate limit state wind pressure of more than 2.5kPa; and 3. includes only windows that comply with AS 2047 has been confirmed via testing to the Verification Method F3V1/H2V1 and is limited to the tested specimen, deviations from this specimen is subject to site specific design and approval by the regulatory authority. **Serviceable Limit State Pressure: ±1.515 kPa** NOTE: Direct fix is not suitable in Climate Zone 6,7 & 8 where a drained and ventilated cavity is required as per Table F8D3 and Table 10.8.1 ***Source:** Test Report No. TS011-18, Weathertightness –Direct Fix dated 01/05/2018 and James Hardie Research Pty Ltd – Advice Note dated 27/10/2022, and James Hardie Research Pty Ltd – Compliance Notification Reference No. JHR/DC20240807 dated 07/08/2024 and Letter of Opinion from James Hardie Research Pty Ltd dated 20/07/2026.*
Condensation Management [F8D3 & H4D9]	Compliance with Condensation Management requires external wall construction in accordance with the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026. Where a pliable building membrane or a sarking-type material is installed as a control layer it must comply with AS 4200.1:2017 must be installed in accordance with AS 4200.2:2017 and must achieve the vapour permeance specified in F8D3(2) or 10.8.1(2) to separate the wall cladding panels from any water sensitive materials. ***Source:** Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guides; Horizontal – September 2026 and Vertical – September 2026.*

Bushfire [G5D3 & H7D4]	An assessment of Stria™ Cladding Smooth and Stria™ Cladding Fine Texture has been completed by Ignis Labs Pty Ltd and is considered to be consistent with, and to satisfy, the requirements of AS 3959:2018 for BAL Low – 40 areas, subject to the installation in accordance with the Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026 or Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026. The PVC Cavity Vent Strip used within Stria™ Cladding Smooth and Stria™ Cladding Fine Texture (305555 Hardie™ 18mm PVC Cavity Vent Strip 3000mm & 306253 Hardie™ 35mm PVC Cavity Vent Strip 3000mm) have been assessed and are considered suitable for use and satisfy the requirements of AS 3959:2018 and maintain compliance with BAL Low – 40 areas. All joints in the external surface material of the wall shall be covered, sealed, overlapped, backed or butt-jointed to prevent gaps greater than 3 mm ***Source:*** *Ignis Labs Pty Ltd Report No. IGNE-260152-99-01R-I04R00 Bushfire Assessment Report issued 24/08/2026.*
Non-combustible [C2D10(6)(d) & H3D2(1)(d)]	Stria™ Cladding Smooth and Stria™ Cladding Fine Texture panels are suitable where non-combustible materials are required in accordance with C2D10(6)(d) and H3D2(1)(d) of the Building Code of Australia as fibre-reinforced cement sheeting that complies with AS/NZS 2908.2:2000. ***Source:*** *James Hardie Research Pty Ltd Test Report Number TS022-10; Testing in accordance with AS/NZS 2908.2:2000 Products Part 2: Flat Sheets; Dated 10/02/2021.*
Wall cladding – Fibre cement [H1D7(4)(b)]	The basic composition is Portland cement, ground sand, cellulose fibre and water. James Hardie building products are manufactured to Australian/New Zealand Standard AS/NZS 2908.2:2000 'Cellulose-cement products-Flat sheet'. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture panels are classified Type A, Category 3 in accordance with AS/NZS 2908.2:2000. ***Source:*** *James Hardie Research Pty Ltd Test Report Number TS022-10; Testing in accordance with AS/NZS 2908.2:2000 Products Part 2: Flat Sheets; Dated 10/02/2021.*

A4 Manufacturer and manufacturing plant(s)

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture weatherboards are manufactured in Australia by James Hardie Australia Pty Ltd. Contact Certificate Holder for details.

A5 Installation requirements

Stria™ Cladding Smooth and Stria™ Cladding Fine Texture must only to be installed in accordance with either;

- Horizontal application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026.
- Vertical application – Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026.

A6 Other relevant technical data

When installing Stria™ Cladding Smooth and Stria™ Cladding Fine Texture in combination with other CodeMark certified Hardie™ Cladding Products, refer to the Hardie™ Architectural Collection Joints and Junctions Application Guide on James Hardie's website. Refer JHR Advisory Note 080920230905 - HAC Opinion Based Upon Tested Prototype Compliance Note dated 14/09/2023.

Resistance to fire	Testing has been conducted by CSIRO on the Hardie™ Cladding materials in accordance with AS/NZS 3837:1998 and are classified as conforming to Group 1 material. (Average Specific Extinction Area 9.3m^2/Kg). For further details, contact the Certificate Holder. ***Source:*** *CSIRO Test Certificate No. 1149 dated 28/08/2008*

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

1. Ancillary Provisions A5G3(1)(e). Reports from a professional engineer.
2. Characteristic Type Testing A5G3(1)(d). Reports from Accredited Testing Laboratories.
3. Condensation Management Provisions A5G3(1)(f). Other forms of documentary evidence.
4. Fire Safety Provision A5G3(1)(d) & (e). Reports from Accredited Testing Laboratories and a professional engineer.
5. Structural Provision A5G3(1)(e). Reports from a professional engineer.
6. Weatherproofing Provisions A5G3(1)(d). Reports from Accredited Testing Laboratories.

B2 Reports

1. Compliance with B1P1(2)(a)&(c) and H1P1(2)(a)&(c) has been confirmed by the following reports:
    a. David Beneke Consulting; Report 2025-04-LO-15; Structural Compliance Certificate of James Hardie Stria Weatherboard External Cladding; Dated 07/02/2025.
    b. David Beneke Consulting Pty Ltd; Report No. 2024-05-LO-75; Certification of James Hardie Structural Castellated Battens Supporting James Hardie External Cladding Systems – Revision 3; Dated 12/03/2024.
2. Compliance with G5D3 and H7D4 has been confirmed by the following reports:
    a. Ignis Labs Pty Ltd Report No. IGNE-260152-99-01R-I04R00; Bushfire Assessment Report; Dated 24/08/2026.
3. Compliance with C2D10(6)(d), H1D7(4)(b) and H3D2(1)(d) has been confirmed by the following reports:
    a. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Report TS022-10; Characteristic Type Tests required by AS/NZS 2908.2:2000; Dated 10/02/2021.
4. Compliance with F3P1 and H2P2 has been confirmed by the following reports:
    a. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Report Reference No. JHR/DC20240807 Compliance Notification – James Hardie Stria™ Cladding Fine Texture Interlocking Joint Similar to James Hardie Stria™ / Oblique™ Interlocking Joint; Dated 07/08/2024.
    b. James Hardie Research Pty Ltd, NATA Accreditation No. 14220; James Hardie Advice Note – Compliance Notification of Stria™ Horizontal and Vertical Fixing Installation (Direct to Frame, and Cavity Installation); Dated 27/10/2022.
    c. James Hardie Research Pty Ltd, NATA Accreditation No. 14220; Test Report Number TS003-13; Cavity Fix Weathertightness; Dated 04/12/2013.
    d. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Report Number TS011-18; Weathertightness compliance report; Dated 01/05/2018.
    e. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Report Number TS022-23; Weathertightness compliance report, Structural Castellated Batten Installation (Cavity Fix) – Clad with James Hardie™ Oblique Vertical Cladding System; Dated 06/12/2023
    f. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Letter of Opinion; Dated 20/07/2026.
5. Compliance with F8D3 and H4D9 has been confirmed by the following documentation:
    a. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Horizontal – October 2026.
    b. Stria™ Cladding Smooth and Stria™ Cladding Fine Texture Installation Guide Vertical – October 2026.

The Certificate Holder has chosen not to make the above evidence of compliance publicly available, due to the documents being considered commercial in confidence.