



Certificate of Conformity

Certificate number: CM40302 Rev2

Certification Body:



ABN: 81 663 250 815
JAS-ANZ Accreditation
No. Z4450210AK
PO Box 273,
Palmwoods Qld 4555
Australia
P: +61 7 5445 2199
www.cmicert.com.au
office@cmicert.com.au

Certificate Holder:



James Hardie Australia
Pty Ltd
ABN: 12 084 635 558
10 Colquhoun St,
Rosehill NSW 2142
Australia
P: 13 11 03
www.jameshardie.com.au

THIS IS TO CERTIFY THAT

Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding

Type and/or use of product:

External cladding on residential and commercial facades.

Description of product:

Fibre-cement cladding.

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2022

	Volume One	Volume Two
Performance Requirement(s):	B1P1(2)(a)&(c) Structural reliability – Permanent and wind actions	H1P1(2)(a)&(c) Structural reliability – Permanent and wind actions
	F3P1 Weatherproofing - External walls subject to Limitation and Condition No. 2.	H2P2 Weatherproofing – External walls subject to Limitation and Condition No. 2.
	G5P1 Construction in bushfire prone areas (BAL Low-40)	H7P5 Construction in bushfire prone areas (BAL Low-40)
Deemed-to-Satisfy Provision(s):	C2D10(6)(d) Non-combustible building elements – Fibre-reinforced cement sheeting – Panel Only	H1D7(4)(b) Wall cladding – Fibre cement
		H3D2(1)(d) Non-combustible building elements – Fibre-reinforced cement sheeting – Panel Only
State or territory variation(s):	G5P1 NSW, QLD, TAS & VIC	H7P5 TAS

SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B

Limitations and conditions:

Building classification/s:

- Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding must only to be installed in accordance with the [Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Installation Guide October 2023](#). Class 1,2,3,4,5,6,7,8,9 & 10
- To satisfy F3P1 & H2P2 via verification requires the site specific evaluation of the relevant design against F3V1 and/or H2V1 to the satisfaction of the Appropriate Authority as defined by the NCC:
 - (a)(i) has a risk score of 20 or less, when the sum of all risk factor scores are determined in accordance with Table F3V1a/H2V1a; and
 - (a)(ii) is not subjected to an ultimate limit state wind pressure of more than 2.5kPa; and
 - (a)(iii) includes only windows that comply with AS 2047.

Richard Donarski – CMI

Don Grehan – Unrestricted Building Certifier

Date of issue: 02/11/2023

Date of expiry: 22/09/2024



Certificate of Conformity

- Compliance with Weatherproofing is limited to the tested specimen detailed in A3, deviations from this specimen, is subject to site specific design and approval by the regulatory authority.
3. In all installations the minimum clearance between the underside of panel and the adjoining ground surface level below must comply with the specifications in Part 7.5.7 of the ABCB Housing Provisions.
 4. No assessment has been undertaken on the product for Part F8 of Vol 1 or Part 10.8 of the ABCB Housing Provisions for Condensation management. A pliable building membrane complying with AS/NZS 4200.1:2017 must be installed in accordance with AS/NZS 4200.2:2017 to separate the wall cladding panels from any water sensitive materials.
 5. Compliance with B1P1(2)(c) & H1P1(2)(c) excludes resistance to impact loading from windborne debris.
 6. Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding must be fixed to a structurally adequate external wall frame in accordance with the appropriate tables in section A5.
 7. Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding comply with H1D7(4)(b) as cladding that satisfies the following sections of Part 7.5 of the ABCB Housing Provisions:
 - a. 7.5.3(a) for wall cladding boards; and
 - b. 7.5.4(1)(a) for sheet wall cladding; and
 - c. 7.5.5(a) for eaves and soffit linings.
 8. The structural certification is limited to the cladding only and does not include the sub-structure. The structural support members are designed and engineered separately as per project requirements by building designers and engineers.
 9. In order to maintain compliance with BAL Low-40, it is the responsibility of the Building Designer to ensure compliance is achieved in accordance with AS 3959-2018.
 10. This certificate is limited to the details within this certificate including the above compliance elements, product description, purpose or use.
 11. Other than the items and information listed, the remainder of the information contained in the product's literature is outside the scope of this certification.
 12. The use of the certified product/system is subject to these Limitations and Conditions and must be read in conjunction with the Scope of Certification below.

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the Certificate Holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Only criteria as identified within this Certificate of Conformity can be used for CodeMark certification claims. Where other claims are made in a client's Installation Manual, Website or other documents that are outside the criteria on this Certificate of Conformity, such criteria cannot be used or claimed to meet the requirements of this CodeMark certification.

The NCC defines a Performance Solution as one that complies with the Performance Requirements by means other than a Deemed-to-Satisfy Solution. A Building Solution that relies on a CodeMark Certificate of Conformity that certifies a product against the Performance Requirements cannot be considered as Deemed-to-Satisfy Solution.

This Certificate of Conformity may only relate to a part of a Performance Solution. In these circumstances other evidence of suitability is needed to demonstrate that the relevant Performance Requirements have been met. The relevant provisions of the Governing Requirements in Part A of the NCC will also need to be satisfied.

This Certificate of Conformity is issued based on the evidence of compliance as detailed herein. Any deviation from the specifications contained in this Certificate of Conformity is outside of this document's scope and the installation of the certified product will not be covered by this Certificate of Conformity.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

When using the CodeMark logo in relation to or on the product/system, the Certificate Holder makes a declaration of compliance with the Scope of Certification and confirms that the product is identical to the product certified herein. In issuing this Certificate of Conformity, CMI Certification Pty Ltd (CMI) has relied on the experience and expertise of external bodies (laboratories and technical experts).

Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding panels are used as an external wall cladding in alterations and additions and residential single and medium density dwellings where a uniform, broadwall cladding is required. Ideal for full wrap or composite construction design on either timber or steel framed homes.

A2 Description of product

Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding panels are pre-primed sheet with a ship lap edge joint along the two long edges. Sheet weighs approximately 12kg/m² in equilibrium.

	Product Code	Length (mm)	Width (mm)	Mass (kg)
Hardie™ Fine Texture Cladding (8.5mm Thick) <small>Note: All dimensions and masses are approximate and subject to manufacturing tolerances</small>	405252	2440	1200	38
	405255	2750	1200	43
	405253	3000	1200	47
	405254	3600	1200	56
	Product Code	Length (mm)	Width (mm)	Mass (kg)
Hardie™ Brushed Concrete Cladding (8.5mm Thick) <small>Note: All dimensions and masses are approximate and subject to manufacturing tolerances</small>	405310	2440	1200	38
	405311	2750	1200	43
	405312	3000	1200	47
	405309	3600	1200	56

Components:

Hardie™ Joint Sealant – General purpose polyurethane exterior grade sealant.

Hardie™ Weather Barrier – Water barrier and vapour permeable membrane compliant to AS/NZS 4200.1:2017.

RAB™ Board – Airtight, weatherproof, vapour permeable and non-combustible rigid 6mm fibre-cement sheeting compliant to AS/NZS 4200.1:2017 & AS/NZS 2908.2:2000.

Hardie™ 9mm Aluminium Horizontal Express Jointer – A horizontal jointer that creates a 6mm horizontal shadow line whilst concealing the edge of the bottom panels.

Hardie™ 9mm Aluminium Recessed Horizontal Jointer – A recessed horizontal jointer that creates a 6mm horizontal shadow line.

Hardie™ 18mm PVC Cavity Vent Strip – A perforated PVC extrusion used at the bottom of walls. Only required if using Hardie™ Cavity Battens.

Hardie™ 9mm Aluminium Base Trim – A trim used to cover the slab edges or as a detail under balconies and cantilevers.

Hardie™ 9mm Aluminium Base Slimline Starter – Aluminium base trim that creates a edge to the cladding whilst improving installation by supporting the bottom of the panel.

Hardie™ 9mm Aluminium External Square Corner – Aluminium extrusion that creates a square edge in external corners.

Hardie™ 9mm Aluminium External Slimline Corner – A external corner.

Hardie™ 9mm Aluminium Internal Concave Corner – A concave internal corner.

Hardie™ 9mm Aluminium Internal Corner – A squared internal corner.

Hardie™ Corner Flashing – Colorbond® steel used behind cladding at internal and external corners.

Hardie™ Axent™ Trim – Material composite trim used for box corners and around windows and doors.

Hardie™ Foam Back Sealing Tape – Installed under sheet vertical joints to improve water tightness.

A3 Product specification

Material The basic composition is Portland cement, ground sand, cellulose fibre and water. James Hardie building products are manufactured to Australian/New Zealand Standard AS/NZS 2908.2:2000 'Cellulose-cement products-Flat sheet'. Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding panels are classified Type A, Category 3 in accordance with AS/NZS 2908.2:2000.

Non-combustible EasyLap™ External cladding panel is suitable where non-combustible materials are required in accordance with as it compliance with C2D10(6)(d) and H3D2(1)(d) of the Building Code of Australia as fibre-reinforced cement sheeting that complies with AS/NZS 2908.2:2000. Non-combustible does not extend to include the joiners for the purpose of C2D10.

Fixing Maximum Stud & Fastener Spacing for Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Including the use of ND50 Brad Nails in AS 4055-2012 Wind Classifications with Option to Fix to Cavity Trim Battens Placed On or Off Stud.

AS 4055-2012 Wind Classification		General Areas of Walls						Within 1200mm of Building Edges					
Non-Cyclonic	Cyclonic	Max Design Pressure (kPa)	Can Battens Be Fixed Off-Stud?	Stud / Batten Spacing (mm)	Batten Fastener Spacing (mm)	Sheet Fastener Spacing (mm)	ND50 Brads (mm)	Max Design Pressure (kPa)	Can Battens Be Fixed Off-Stud?	Stud / Batten Spacing (mm)	Batten Fastener Spacing (mm)	Sheet Fastener Spacing (mm)	ND50 Brads (mm)
N1, N2, N3	C1	-0.98	YES	600	300	200	125	-1.95	YES	600	300	200	125
N4	C2	-1.45	YES	600	300	200	-	-2.90	NO	450	200	150	-
N5	C3	-2.14	NO	600	200	200	-	-4.27	NO	300	200	150	-
N6	C4	-2.88	NO	450	200	150	-	-5.77	NO	300	200	125	-

Weatherproofing Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding – Direct Fixed

Testing was conducted in accordance with the Verification Method FV1. Current against 2022 Verification Method F3V1 'Weatherproofing' (Volume 1) and H2V1 'Weatherproofing' (Volume 2) test procedure as contained within Building Code of Australia.

Results

Test Type	Criteria	Result
Structural Test	100% Serviceability Limit State Pressure of 1.230 kPa for 1 minute in both positive and negative directions.	Pass
Static Water Penetration	30% Serviceability Limit State Pressure 369 Pa for 15 minutes Pass Criteria: No presence of water on the inside surface of the façade.	Pass - No leak observed on the inside surface of the building wrap.
Cyclic Water Penetration	Cyclic @ 15-30% SLS –184 to 369 Pa Duration: 5 minutes Cyclic @ 20-40% SLS –246 to 492 Pa Duration: 5 minutes Cyclic @ 30-60% SLS –369 to 738 Pa Duration: 5 minutes Pass Criteria: No presence of water on the inside surface of the facade.	Pass - No leak observed non the inside surface of the building wrap.

Source: Test Report No. TS008-20 Weathertightness-EasyTex Cladding (Direct Fix)-NCC Compliance dated 3 June 2020.

Bushfire

An assessment of the Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding fibre-reinforced cement sheeting wall system has been completed by Ignis Labs Pty Ltd. AS 3959:2018 allows external wall cladding for BAL 12.5 to BAL 40 to be non-combustible material or fibre cement a minimum 9mm in thickness and the total wall system is at least 90mm in thickness. The Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding, which are 8.5mm have been assessed for use in BAL 40 applications.

The following list details the various PVC joiners used within the Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding system. These joiners have been assessed and are considered suitable for use and have the ability to satisfy the requirements of AS 3959:2018 and maintain compliance with BAL – 40 areas.

- 305555 Hardie™ 18mm PVC Cavity Vent Strip 3000mm

Source: Ignis Labs Pty Ltd Report No. IGNL-6249-16-01 I02R05 BBV3.0 JH Bushfire 05102023 dated 05/10/2023.

A4 Manufacturer and manufacturing plant(s)

Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Panels are manufactured in Australia by James Hardie Australia Pty Ltd. Contact Certificate Holder for details.

A5 Installation requirements

Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Panels must only to be installed in accordance with the [Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Installation Guide October 2023](#).

A suitable weather barrier must be installed behind Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Panels in accordance with the relevant requirements of the BCA and AS/NZS 4200.2:2017 Pliable building membranes and underlays – Installation. James Hardie recommends HardieWrap™ Weather Barrier – refer to the building designer, certifier, or other relevant expert, for suitability.

Refer to the [Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Installation Guide October 2023](#), for Stud Spacings and fixing requirements.

A6 Other relevant technical data

When installing Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding Panels in combination with other CodeMark certified Hardie™ Cladding Products, refer to the [Hardie™ Architectural Collection Joints and Junctions Application Guide](#). The construction drawings presented on the Application Guide have been reviewed, based on the requirements of NCC 2022 Vol 1 and 2 as described on the 080920230905 – JHR Advisory Note – HAC Opinion Based Upon Tested Prototype Compliance Note V1.1. Compliance to Weatherproofing provision is subject to Limitation and Conditions No. 2 as outlined on this Certificate of Conformity.

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

1. Ancillary Provisions A5G3(1)(e). Reports from a professional engineer.
2. Fire Safety Provision A5G3(1)(e). Reports from a professional engineer.
3. Structural Provision A5G3(1)(e). Reports from a professional engineer.
4. Weatherproofing Provision A5G3(1)(d). Reports from Accredited Testing Laboratories.

B2 Reports

1. David Beneke Consulting; Report 2019-12-LO-14; Structural compliance; Dated 27/05/2020. Report provide compliance with B1P1(2)(a)&(c) and H1P1(2)(a)&(c).
2. Cardno (NSW/ACT) Pty Ltd; Report 605726-LO-07-3; Certification of James Hardie cladding panels; Dated 03/10/2019. Report provide compliance with B1P1(2)(a)&(c) and H1P1(2)(a)&(c).
3. Stantec Australia Pty Ltd; Reference No. 304000206_230412; Structural Certification; Dated 12/04/2023. Report provide compliance with B1P1(2)(a)&(c) and H1P1(2)(a)&(c).
4. Ignis Labs Pty Ltd Report No. IGNU-6249-16-01 I02R05 BBV3.0 JH Bushfire 05102023; Compliance with AS 3959-2009 BAL Low-40; Dated 05/10/2023. Report confirms the BAL of Hardie™ Fine Texture Cladding and Hardie™ Brushed Concrete Cladding that complies with G5P1 and H7P5.
5. CSIRO; Reference No. FCO-2844/CO4787; Assessment of BAL to AS 1530.8.1:2007; Revision C; Dated 26/06/2020. Report provides supporting evidence for compliance with BAL with G5P1 and H7P5.
6. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Certificate No. TS008-20 FV1.1 / V2.2.1 Weatherproof testing; Dated 03/06/2020. Report confirms compliance with F3P1 and H2P2.
7. James Hardie Research Pty Ltd; NATA Accreditation No. 14220; Test Certificate No. TS019-16 AS/NZS 2908.2-2000 Report 27072020; Dated 27/07/2020. Report confirms the fibre-reinforced cement sheeting complies with AS/NZS 2908.2:2000 and meets the requirements for C2D10(6)(d), H1D7(4)(b) and H3D2(1)(d).
8. Acronem Consulting Australia Pty Ltd; James Hardie RAB Board properties compared to AS/NZS 4200.1:2017; Dated 06/08/2020. Report provides supporting evidence for compliance with F3P1 and H2P2.

The Certificate Holder has chosen not to make the above evidence of compliance publicly available, due to the documents being considered commercial in confidence.