

CERTIFICATE OF CONFORMITY

This is to certify that

Linyi Millennium Dream Decoration Materials Co., Ltd.

Is certified to manufacture products to:

AS 6669:2016 Plywood – Formwork AS/NZS 2269.0:2012 Plywood - Structural Specifications

Certificate Holder

Linyi Millennium Dream Decoration Materials Co., Ltd.

Qianjie Village, Fangcheng Town, Lanshan District, Linyi City, Shandong Province 276000 China

Product Description

Formwork Plywood & Structural Plywood

Product Purpose or Use

Formwork Plywood & Structural Plywood

Subject to the following Conditions & Limitations:

Nil

Certification Body

CERTIFICATION

CMI Certification Pty Ltd

ABN: 81 663 250 815 JAS-ANZ Accreditation No. Z4450210AK PO Box 273, Palmwoods Qld 4555, Australia

> Ph: +61 7 5445 2199 E: office@cmicert.com.au W: https://cmicert.com.au/

Certificate No: PC10141

Originally Certified: 18/09/2025 **Updated:** 18/09/2025 **Expires:** 18/09/2030

Talissa Ireland
CMI Certification Pty Ltd



[•] It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website https://register.cmicert.com.au/



PC10141-I01-R00



CERTIFICATE OF CONFORMITY

This is to certify that

Linyi Millennium Dream Decoration Materials Co., Ltd.

Is certified to manufacture products to:

AS 6669:2016 Plywood – Formwork

Brand	Model	Description	Date Endorsed
HEND	F11	12mm Formply Plywood – Poplar & Eucalyptus – CD, A Bond, Super E_0 , Class 2 F11 (I 71.1 – Z 11.9 / I 69.5 – Z 12.9) Parallel: E 11450 MPa; f_b' 48.52 MPa; f_s' 6.33 MPa; Perpendicular: E 16650 MPa; f_b' 50.07 MPa; f_s' 6.89 MPa	18/09/2025
HEND	F17	17mm Formply Plywood – Poplar & Eucalyptus – CD, A Bond, Super E ₀ , Class 2 F17 (I 217.0 – Z 25.2 / I 210.6 – Z 26.9) Parallel: E 14850 MPa; f_b' 70.79 MPa; f_s' 6.02 MPa; Perpendicular: E 14850 MPa; f_b' 62.99 MPa; f_s' 5.49 MPa	18/09/2025

AS/NZS 2269.0:2012 Plywood - Structural Specifications

Brand	Model	Description	Date Endorsed
HEND	F14	4mm Structural Plywood – Larch & Eucalyptus – CD, A Bond, Super E ₀ , F14-4 (I 6.1 – Z 2.9 / I 0.2 – Z 0.3) Parallel: E 13550 MPa; f_b' 89.26 MPa; f_s' 5.31 MPa; f_t' 24.58 MPa; f_c' 27.89 MPa Perpendicular: E 23800 MPa; f_b' 106.20 MPa; f_s' 5.54 MPa; f_t' 26.93 MPa; f_c' 31.58 MPa	18/09/2025
HEND	F17	17mm Structural Plywood – Radiata Pine & Eucalyptus – CD, A Bond, Super E ₀ , F17-17 (I 178.9 – Z 21.4 / I 210.6 – Z 26.9) Parallel: E 15100 MPa; f_b' 62.20 MPa; f_s' 5.99 MPa; f_t' 27.24 MPa; f_c' 36.89 MPa Perpendicular: E 14600 MPa; f_b' 55.48 MPa; f_s' 5.38 MPa; f_t' 32.72 MPa; f_c' 40.35 MPa	18/09/2025

End of Record

Certificate No: PC10141 **Originally Certified:** 18/09/2025 **Updated:** 18/09/2025 **Expires:** 18/09/2030



PC10141-I01-R00

[•] The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For futher information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.

[•] It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website https://register.cmicert.com.au.