



CMI ProdCert
PC10161

CERTIFICATE OF CONFORMITY

This is to certify that

Nova Fire Systems

Is certified to manufacture products to:

AS ISO 7240.24:2018 Fire detection and alarm systems Part 24: Fire alarm loudspeakers

Certificate Holder

Nova Fire Systems
ABN: 40 625 741 540
U99, 2 The Crescent, Kingsgrove NSW
2208 Australia

Product Description

Fire Alarm Loudspeakers

Product Purpose or Use

Fire Alarm Loudspeakers

Subject to the following Conditions & Limitations:

Nil

Certification Body



CMI Certification Pty Ltd
ABN: 81 663 250 815
JASANZ Accreditation No. Z4450210AK
PO Box 273, Palmwoods Qld 4555,
Australia
Ph: +61 7 5445 2199
E: office@cmicert.com.au
W: <https://cmicert.com.au/>

Certificate No: PC10161

Originally Certified: 11/11/2025

Updated: 11/11/2025

Expires: 11/11/2030

Talissa Ireland
CMI Certification Pty Ltd



- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>





CERTIFICATE OF CONFORMITY

This is to certify that

Nova Fire Systems

Is certified to manufacture products to:

AS ISO 7240.24:2018 Fire detection and alarm systems Part 24: Fire alarm loudspeakers

Brand	Model Identification	Product	Product Description	Performance	Type	Date Endorsed
Nova Fire	CRS-66A	Ceiling Speaker	Ceiling Speaker 200mm x 90mm with transformer. Metal enclosure, metal grille and fire dome in white. Ceramic connector and thermal fuse	Rated Power Output: 6 /3 /1.5 /0.75 W Line Input: 100V or 70V Frequency Response: 100-18KHz SPL(@1W/m): 92dB	Type A	11/11/2025
Nova Fire	SMS-56A	Wall Mount Speaker	Wall Mount Speaker 165mm x 165mm x 60mm with transformer. Metal enclosure, metal grille and fire dome in white. Ceramic connector and thermal fuse	Rated Power Output: 1.5W-3W-6W Line Input: 100V or 70V Frequency Response: 120-10KHz SPL(@1W/m): 92dB / Max 99dB	Type A	11/11/2025
Nova Fire	HS-15B	Outdoor Horn Speaker	Outdoor Horn Speaker 237mm x 175mm x 236mm with transformer. ABS enclosure with stainless aluminium bracket in white. Ceramic connector, junction box and thermal fuse	Rated Power Output: 15W/7.5W/3.75W/1.9W 8 Ohm Line Input: 100V or 70V Frequency Response: 400-8KHz SPL(@1W/m): 110dB IP Rate: IP66	Type B	11/11/2025
Nova Fire	PJ-20B	Speaker	Speaker 170mm x 245mm with transformer. ABS enclosure and stainless metal bracket in white. Ceramic connector and thermal fuse	Rated Power Output: 5W-10W-20W at 100V 8 Ohm Line Input: 100V or 70V Frequency Response: 110-18KHz SPL(@1W/m): 92dB / Max 95dB IP Rate: IP66	Type B	11/11/2025

End of Record

Certificate No: PC10161

Originally Certified: 11/11/2025

Updated: 11/11/2025

Expires: 11/11/2030

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>

