

CERTIFICATE OF CONFORMITY

This is to certify that

One20 Pty Ltd

Is certified to manufacture products to:

**AS 1905.1:2015 Components for the protection of openings in fire-resistant walls
Part 1: Fire resistant doorsets
(Section 3 compliance to AS 1530.4:2014 testing)**



CMI ProdCert
PC10118

Certificate Holder

ONE20 Pty Ltd
17/3 Westside Avenue, Port Melbourne
VIC 3207 Australia
ACN: 673 534 720

Certification Body



CMI Certification Pty Ltd
ABN: 81 663 250 815
JAS-ANZ Accreditation No.
Z4450210AK
PO Box 273, Palmwoods Qld 4555,
Australia
Ph: +61 7 5445 2199
E: office@cmicert.com.au
W: <https://cmicert.com.au/>

Product Description

Fire Resistant Door & Doorframe

Product Purpose or Use

Fire Resistant Door & Doorframe

Subject to the following Conditions & Limitations:

Certification does not cover hardware or installation. All hardware utilised on these doors & doorframe MUST comply with AS 1905.1:2015 requirements and the corresponding FRL for the door & doorframe. All installation MUST comply with AS 1905.1:2015 requirements. Final compliance marking & tagging of doorframe and door leaf MUST comply with AS 1905.1:2015 requirements after all hardware is fitted and the door and doorframe are installed.

Certificate No: PC10118

Originally Certified: 10/04/2025

Updated: 20/02/2026

Expires: 10/04/2030

Talissa Ireland
CMI Certification Pty Ltd



- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>



CERTIFICATE OF CONFORMITY

This is to certify that

One20 Pty Ltd

Is certified to manufacture products to:

AS 1905.1:2015 Components for the protection of openings in fire-resistant walls

Part 1: Fire resistant doorsets

(Section 3 compliance to AS 1530.4:2014 testing)



Brand	Model	Description	Dimensions	FRL	Date Endorsed
One20	GMFM-1125-d5 A2.00-1 (55 mm)	Door Frame - Galvanised Steel Frame (1.2 mm thick) with infilled Perlite. Door Leaf - Single Wooden Leaf (3 mm Plywood + 9 mm Calcium Silicate Board + 31 mm Perlite + 9 mm Calcium Silicate Board + 3 mm Plywood, Fire Resistant Door & Doorframe. Rebate 20 mm. Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/60, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door Frame Size: 1087 mm(W) x 2448 mm(H) x 140 mm(T) Door Leaf Size: 1000 mm(W) x 2400 mm(H) x 55 mm(T)	-/120/60	10/04/2025
One20	GMFM-1125-d5 A1.00-1 (47 mm)	Door Frame - Galvanised Steel Frame (1.2 mm thick) with infilled Perlite. Door Leaf - Single Wooden Leaf (3 mm MDF + 5 mm Calcium Silicate Board + 31 mm Perlite + 5 mm Calcium Silicate Board + 3 mm MDF, Fire Resistant Door & Doorframe. Rebate 20 mm. Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/60/60, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door Frame Size: 1087 mm(W) x 2448 mm(H) x 140 mm(T) Door Leaf Size: 1000 mm(W) x 2400 mm(H) x 47 mm(T)	-/60/60	10/04/2025
One20	GMFM-2125-d5 A2.00-2 (55 mm)	Door Frame - Galvanised Steel Frame (1.2 mm thick) with infilled Perlite. Door Leaf - Double Wooden Leaves (3 mm Plywood + 9 mm Calcium Silicate Board + 31 mm Perlite + 9 mm Calcium Silicate Board + 3 mm Plywood, Fire Resistant Door & Doorframe. Rebate 20 mm.	Door Frame Size: 2090 mm(W) x 2448 mm(H) x 140 mm(T) Door Leaf Size: 1000 mm(W) x 2400 mm(H) x 55 mm(T)	-/120/90	10/04/2025

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>



		Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/90, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015			
One20	GMFF-1125-d5 A2.00-1 (140 mm)	Door Frame - Galvanised Steel Frame (1.2 mm thick) with infilled Perlite. Rebate 20 mm Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/60, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door frame size: 1087 mm(W) x 2448 mm(H) x 140 mm(T)	-/120/60	20/02/2026
One20	GMFD-1125-d5 A2.00-1 (55 mm)	Door Leaf - Single Wooden Leaf (3 mm Plywood + 9 mm Calcium Silicate Board + 31 mm Perlite + 9 mm Calcium Silicate Board + 3 mm Plywood, Fire Resistant Door. Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/60, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door leaf size: 1000 mm(W) x 2400 mm(H) x 55 mm(T)	-/120/60	20/02/2026
One20	GMFF-1125-d5 A1.00-1 (140 mm)	Door Frame - Galvanised Steel Frame (1.2 mm thick) with infilled Perlite. Rebate 20 mm Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/60/60, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door frame size: 1087 mm(W) x 2448 mm(H) x 140 mm(T)	-/60/60	20/02/2026
One20	GMFD-1125-d5 A1.00-1 (47 mm)	Door Leaf - Single Wooden Leaf (3 mm MDF + 5 mm Calcium Silicate Board + 31 mm Perlite + 5 mm Calcium Silicate Board + 3 mm MDF, Fire Resistant Door. Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/60/60, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door leaf size: 1000 mm(W) x 2400 mm(H) x 47 mm(T)	-/60/60	20/02/2026
One20	GMFF-2125-d5 A2.00-2 (140 mm)	Door Frame - Galvanised Steel Frame (1.2 mm thick) with infilled Perlite. Rebate 20 mm Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/90, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door frame size: 2090 mm(W) x 2448 mm(H) x 140 mm(T)	-/120/90	20/02/2026
One20	GMFD-2125-d5 A2.00-2 (55mm)	Door Leaf - Double Wooden Leaves (3 mm Plywood + 9 mm Calcium Silicate Board + 31 mm Perlite + 9 mm Calcium Silicate Board + 3 mm Plywood, Fire Resistant Door. Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/90, cannot be installed on this One20 Fire-Resistant Doorset. Installation must be done in accordance with AS 1905.1:2015	Door leaf size: 1000 mm(W) x 2400 mm(H) x 55 mm(T)	-/120/90	20/02/2026

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmcert.com.au/>

One20	KIN LONG -1125-bd5 A2.00-1 (55 mm)	<p>Door Frame - Galvanized Steel Frame (1.2 mm thick) with Infilled Perlite Door Leaf - Single Wooden Leaf (3 mm Plywood + 9 mm Calcium Silicate Board + 31 mm Perlite + 9 mm Calcium Silicate Board + 3 mm Plywood, Fire Resistant Door & Doorframe. Rebate 20mm.</p> <p>KIN LONG Hardware: Lockset: ST7092AD Lever Handle: SMB10214 Cylinder: SX-008 Door Closure: B804 – Aluminium Hinges: SHY403030 – Stainless Steel SUS304 Drop Seal: SDS43002 – Aluminium + Silicone Sealing Strip</p> <p>KIN LONG Hardware has been tested with this doorset to AS 1530.4:2014 and corresponding FRL of -/120/120. Hardware has not been validated to AS 1905.1:2015. Installation must be done accordance with AS 1905.1:2015</p>	<p>Door frame size: 1088 mm(W) x 2448 mm(H) x 140 mm(T) Door leaf size: 1000 mm(W) x 2400 mm(H) x 55 mm(T) Lockset: 31.5mm x 203mm x 104.5mm Lever Handle: Ø19mm x 71mm x 125mm Cylinder: Ø34.5mm x 35mm Door Closure: 206mm x 44.5mm x 68mm Hinges: 4" x 3" x 3.0mm Drop Seal: 32mm x 34mm</p>	-/120/120	20/02/2026
One20	GMFM-1125-bd5 A2.00-1 (55 mm)	<p>Door Frame - Galvanized Steel Frame (1.2 mm thick) with Infilled Perlite. Door Leaf - Single Wooden Leaf (3 mm Plywood + 9 mm Calcium Silicate Board + 31 mm Perlite + 9 mm Calcium Silicate Board + 3 mm Plywood, Fire Resistant Door with 45mm thick Glass Window (Nano-Silica & White Glass). Rebate 20mm.</p> <p>Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/120, cannot be installed on this One20 Fire- Resistant Doorset. Installation must be done accordance with AS 1905.1:2015</p>	<p>Door frame size: 1088 mm(W) x 2448 mm(H) x 140 mm(T) Door leaf size: 1000 mm(W) x 2400 mm(H) x 55 mm(T) Window Aperture: 186mm x 736mm Window Vision: 150mm x 700mm</p>	-/120/120	20/02/2026
One20	GMFD-1125-bd5 A2.00-1 (55 mm)	<p>Door Leaf - Single Wooden Leaf (3 mm Plywood + 9 mm Calcium Silicate Board + 31 mm Perlite+ 9 mm Calcium Silicate Board + 3 mm Plywood, Fire Resistant Door with 45mm thick Glass Window (Nano-Silica & White Glass).</p> <p>Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/120, cannot be installed on this One20 Fire- Resistant Doorset. Installation must be done accordance with AS 1905.1:2015</p>	<p>Door leaf size: 1000 mm(W) x 2400 mm(H) x 55 mm(T) Window Aperture: 186mm x 736mm Window Vision: 150mm x 700mm</p>	-/120/120	20/02/2026
One20	GMFF-1125-bd5 A2.00-1 (55 mm)	<p>Door Frame - Galvanized Steel Frame (1.2 mm thick) with infilled Perlite. Rebate 20 mm</p> <p>Hardware which has not been validated to AS 1905.1:2015 and corresponding FRL of -/120/120, cannot be installed on this One20 Fire- Resistant Doorset. Installation must be done accordance with AS 1905.1:2015</p>	<p>Door frame size: 1088 mm(W) x 2448 mm(H) x 140 mm(T)</p>	-/120/120	20/02/2026

End of Record

Certificate No: PC10118

Originally Certified: 10/04/2025

Updated: 20/02/2026

Expires: 10/04/2030

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmcert.com.au/>

