



Certificate of Conformity

THIS CERTIFICATE IS GRANTED TO

Precision Flow Solutions

4/185 Briens Road, Northmead, NSW 2152, Australia

ABN: 81 144 394 531

W: www.preflow.com.au

T: +61 2 9625 8122

Subject to the following conditions and limitations:

1. The Approved Certifier grants the right to use of the WaterMark as shown in the top left corner only in respect of the Products described and detailed on the Product Schedule following which are produced by the Approved User and which comply with the appropriate Applicable Specification referenced below and as amended from time to time. The Licence is granted subject to the rules governing the use of the WaterMark and the terms and conditions for certification. The WaterMark Licensee covenants to comply with all the Rules, technical reference documents and terms and conditions of the WaterMark Certification Scheme.
2. The Certified products must be installed in accordance with the current version of the Plumbing Code of Australia and requirements of S41C1 of NCC 2022 Volume 3.
3. Nothing in this document should be construed as a warranty or guarantee by CMI Certification (CMI), and the only applicable warranties will be those provided by the Certificate Holder.
1. Information contained herein or related hereto is intended only for evaluation by technically skilled persons, with any use thereof to be at their independent discretion and risk. Such information is believed to be reliable, but CMI shall have no responsibility or liability for results obtained or damages resulting from such use. CMI grants no license under and shall have no responsibility or liability for infringement of, any patent or other proprietary right. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate holder.

Talissa Ireland

CMI Certification Pty Ltd

PO Box 273, Palmwoods, Qld 4555, Australia

ABN: 81 663 250 815

T: + 61 7 5445 2199

W: www.cmcert.com.au

E: office@cmcert.com.au



080047	14/06/2019	28/08/2026	13/06/2029	WMTS-101:2025 Appliances and commercial catering equipment
--------	------------	------------	------------	--

**CERTIFICATE
NUMBER**

**INITIAL
CERTIFICATION DATE**

**CURRENT
CERTIFICATION DATE**

**CERTIFICATION
EXPIRY DATE**

**APPLICABLE
STANDARD/SPECIFICATION**

This Certificate is issued by a JASANZ accredited certification body. The Scheme Owner, Administering Body and Accreditation Body do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The Scheme Owner disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate.

The WaterMark is a registered certification trademark of the Scheme Owner (ABN 74 599 608 295). The rules of the WaterMark Certification Scheme are available from the ABCB website www.abcb.gov.au





Schedule To

APPLICABLE STANDARD/SPECIFICATION

WMTS-101:2025 Appliances and commercial catering equipment



Brand Name	Model Name	Model Identification	Product Description	Scope of Use	Lead Free* Yes/No/Not Applicable	Date Endorsed
Hydro	HydroChem	PFS918	Chemical Dispenser - Inline Venturi - Single Product - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	HydroChem	PFS919	Chemical Dispenser - Inline Venturi - Dual Product - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	Foam Master	PFS89X	Chemical Dispenser - Inline Venturi - Single Product - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	Foam Master	PFS897	Chemical Dispenser - Inline Venturi - Single Product - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026

Hydro	Foam Master	PFS898	Chemical Dispenser - Inline Venturi - Single Product - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	Foam Master	PFS89X	Chemical Dispenser - Inline Venturi - Dual Product - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	Foam Master	PFS899	Chemical Dispenser - Inline Venturi - Dual Product - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	FM Flush Manifold	PFSFM-8XX	Chemical Dispenser - Inline Venturi - 1 to 8 Products - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 60°C. Inlet Size: ½" Hose Barb Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	FM Flush Manifold	PFSFM-804	Chemical Dispenser - Inline Venturi - 1 to 8 Products - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 60°C. Inlet Size: ½" Hose Barb Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	FM Flush Manifold	PFSFM-806	Chemical Dispenser - Inline Venturi - 1 to 8 Products - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 172 kPa. Maximum Inlet Pressure: 586 kPa. Maximum Water Temp: 60°C. Inlet Size: ½" Hose Barb Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026

Hydro	EvoClean	PFS12XXGB	Chemical Dispenser - Inline Venturi - 1 to 8 Products - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 179 kPa. Maximum Inlet Pressure: 414 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	EvoClean	PFS1214	Chemical Dispenser - Inline Venturi - 1 to 8 Products - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 179 kPa. Maximum Inlet Pressure: 414 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	EvoClean	PFS1221	Chemical Dispenser - Inline Venturi - 1 to 8 Products - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 179 kPa. Maximum Inlet Pressure: 414 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	EvoClean	PFS1233	Chemical Dispenser - Inline Venturi - 1 to 8 Products - Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 179 kPa. Maximum Inlet Pressure: 414 kPa. Maximum Water Temp: 48°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	Sprite DM 420 Series	DM-411	Chemical Dispenser – Warewash Unit – Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 138 kPa. Maximum Inlet Pressure: 414 kPa. Maximum Water Temp: 49°C. Inlet Size: 6mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026

Hydro	AquaBlend	PFS117xxx	Chemical Dispenser – Inline Water Driven – Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 34 kPa. Maximum Inlet Pressure: 620 kPa. Maximum Water Temp: 38°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	AquaBlend	PFS117957	Chemical Dispenser – Inline Water Driven – Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 34 kPa. Maximum Inlet Pressure: 620 kPa. Maximum Water Temp: 38°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026
Hydro	AquaBlend	PFS117958	Chemical Dispenser – Inline Water Driven – Single Outlet with Brass RPZ-20 Backflow Prevention RPZD, Brass Ball Valve & Brass Strainer	Wall mounted Chemical Dispenser with a low risk of back siphonage and an external Backflow Prevention Device. Not for the supply of Drinking Water. Minimum Inlet Pressure: 34 kPa. Maximum Inlet Pressure: 620 kPa. Maximum Water Temp: 38°C. Inlet Size: 20mm BSP Must be installed in accordance with the current version of the Plumbing Code of Australia	N/A	28/08/2026

*Lead Free compliance in accordance with NCC 2025 - Volume Three – Plumbing Code of Australia - A5G4(2)(b)

End of Record