



# Certificate of Conformity

THIS CERTIFICATE IS GRANTED TO

## PureFlow Solutions Pty Ltd

9 Oakfield Ct, Frankston South, VIC 3199 Australia

ABN: 23 671 141 521

T: +61 3 9088 3007

W: <https://pureflowfiltration.com.au/>

### Subject to the following conditions and limitations:

1. The Approved Certifier grants the right to use or arrange the use of the WaterMark as shown in the top left corner only in respect of the Products described and detailed on the Product Schedule following which are produced by the Approved User and which comply with the appropriate Applicable Specification referenced below and as amended from time to time. The Licence is granted subject to the rules governing the use of the WaterMark and the terms and conditions for certification. The WaterMark Licensee covenants to comply with all the Rules, technical reference documents and terms and conditions of the WaterMark Certification Scheme.
2. The Certified products must be installed in accordance with the current version of the Plumbing Code of Australia.
3. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.
4. Information contained herein or related hereto is intended only for evaluation by technically skilled persons, with any use thereof to be at their independent discretion and risk. Such information is believed to be reliable, but CMI Certification Pty Ltd (CMI) shall have no responsibility or liability for results obtained or damages resulting from such use. CMI grants no license under, and shall have no responsibility or liability for infringement of, any patent or other proprietary right. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate holder.

Talissa Ireland

**CMI Certification Pty Ltd**

PO Box 273, Palmwoods, Qld 4555, Australia

ABN: 81 663 250 815

T: + 61 7 5445 2199

W: [www.cmcert.com.au](http://www.cmcert.com.au)

E: [office@cmcert.com.au](mailto:office@cmcert.com.au)



080127	23/02/2026	01/05/2026	30/04/2028	AS 3497:2021 – Water filters and water treatment appliances
--------	------------	------------	------------	---

CERTIFICATE NUMBER	INITIAL CERTIFICATION DATE	CURRENT CERTIFICATION DATE	CERTIFICATION EXPIRY DATE	APPLICABLE STANDARD/SPECIFICATION
--------------------	----------------------------	----------------------------	---------------------------	-----------------------------------

This Certificate is issued by a JAS-ANZ accredited certification body. The Scheme Owner, Administering Body and Accreditation Body do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The Scheme Owner disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate.

The WaterMark is a registered certification trademark of the Scheme Owner (ABN 74 599 608 295). The rules of the WaterMark Certification Scheme are available from the ABCB website [www.abcb.gov.au](http://www.abcb.gov.au)





# Schedule To

## PureFlow Solutions Pty Ltd



APPLICABLE  
STANDARD/SPECIFICATION

AS 3497:2021 – Water filters and water treatment appliances

Brand Name	Model Name	Model Identification	Product Description	Scope of Use	Lead Free* Yes/No**/Not Applicable	Date
PureFlow	WHF10-1	WHF10-1	Water Purifier – Chlorine Reduction - Category V – 304 Stainless Steel Mount, Standing Frame & Cover with 3 x 10" x 4.5 PP Filter Housings – 1 x PWF-10PP Filter – 2 x PWF-10CTO Filters - 2 x Pressure Gauges	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	No	23/02/2026
PureFlow	WHF10	WHF10	Whole Home Water Filter – 304 Stainless Steel Mount, Standing Frame & Cover with 3 x 10" x 4.5 PP Filter Housings – 1 x PP-10 Filter – 1 x CTO/Antiscale-10 Filter – 1 x LRC/CTO-10 Filters - 3 x Pressure Gauges	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	No	23/02/2026
PureFlow	WHF15-1	WHF15-1	Water Purifier – Chlorine Reduction - Category V – 304 Stainless Steel Mount, Standing Frame & Cover with 3 x 15" x 4.5 PP Filter Housings – 1 x PWF-15PP Filter – 2 x PWF-15CTO Filters - 2 x Pressure Gauges	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	No	23/02/2026
PureFlow	WHF15	WHF15	Water Purifier – Chlorine Reduction - Category V – 304 Stainless Steel Mount, Standing Frame & Cover with 3 x 15" x 4.5 PP Filter Housings – 1 x PWF-15PP Filter – 2 x PWF-15CTO Filters - 3 x Pressure Gauges	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	No	23/02/2026
PureFlow	WHF20-1	WHF20-1	Water Purifier – Chlorine Reduction - Category V – 304 Stainless Steel Mount, Standing Frame & Cover with 3 x 20" x 4.5 PP Filter Housings – 1 x PWF-20PP Filter – 2 x PWF-20CTO Filters - 2 x Pressure Gauges	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	No	23/02/2026

PureFlow	WHF20	WHF20	Whole Home Water Filter – 304 Stainless Steel Mount, Standing Frame & Cover with 3 x 20" x 4.5 PP Filter Housings – 1 x PP-20 Filter – 1 x CTO/Antiscale-20 Filter – 1 x LRC/CTO-20 Filters - 3 x Pressure Gauges	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	No	23/02/2026
PureFlow	PWF-10PP	PWF-10PP	10" Filter – 1-10 micro aperture for 10" x 4.5 size housing	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	N/A	23/02/2026
PureFlow	PWF-10CTO	PWF-10CTO	10" Filter – 5 micro aperture for 10" x 4.5 size housing	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	N/A	23/02/2026
PureFlow	PWF-15PP	PWF-15PP	15" Filter – 1-10 micro aperture for 15" x 4.5 size housing	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	N/A	23/02/2026
PureFlow	PWF-15CTO	PWF-15CTO	15" Filter – 5 micro aperture for 15" x 4.5 size housing	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	N/A	23/02/2026
PureFlow	PWF-20PP	PWF-20PP	20" Filter – 1-10 micro aperture for 20" x 4.5 size housing	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	N/A	23/02/2026
PureFlow	PWF-20CTO	PWF-20CTO	20" Filter – 5 micro aperture for 20" x 4.5 size housing	Nominal Flow Rate: 30L/min Min Inlet Water Pressure: 0.2MPa Max Inlet Water Pressure: 0.8MPa Min Operating Temp: 5°C Max Operation Temp: 38°C	N/A	23/02/2026

\*Lead Free compliance in accordance with NCC 2022 - Volume Three – Plumbing Code of Australia - A5G4(2)(b)

\*\* Product is not Lead Free compliant

**End of Record**