



CMI ProdCert
PC10103

CERTIFICATE OF CONFORMITY

This is to certify that

Shanghai Aoland Building Materials Limited

Is certified to manufacture products to:

AS 2047-2014 Windows and external glazed doors in buildings

Certificate Holder

**Shanghai Aoland Building
Materials Limited**

No.128, Lane 255, East Touqiao Rd,
Fengxian District, Shanghai 201409
China

Product Description

Windows and external glazed doors

Product Purpose or Use

Windows and external glazed doors

Subject to the following Conditions & Limitations:

Nil

Certification Body



CMI Certification Pty Ltd

ABN: 81 663 250 815

JAS-ANZ Accreditation No.

Z4450210AK

PO Box 273, Palmwoods Qld 4555,
Australia

Ph: +61 7 5445 2199

E: office@cmicert.com.au

W: <https://cmicert.com.au/>

Certificate No: PC10103

Originally Certified: 03/02/2025

Updated: 03/02/2025

Expires: 03/02/2030

Talissa Ireland

CMI Certification Pty Ltd



- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>



CMI ProdCert
PC10103

CERTIFICATE OF CONFORMITY

This is to certify that

Shanghai Aoland Building Materials Limited

Is certified to manufacture products to:

AS 2047-2014 Windows and external glazed doors in buildings

| Brand | Model Identification | Product | Product Description | Performance | Date Endorsed |
|--------|----------------------|-----------------------|---|--|---------------|
| AOLAND | AD418 | Awning & Fixed Window | Non-Thermal Break Aluminium Awning & Window – 1600mm(W) x 2400mm(H) x 100mm(T) - Operable Sash 735mm(W) x 1137mm(H) - Fixed Sash 800mm(W) x 2400mm(H) with AS/NZS 2208:1996, AS 2208:2023 & AS 4666:2012 Glazing Model: 6063-T5 | Serviceability Limit Pressure: 1200 Pa Ultimate Strength Pressure: 4000 Pa Water Penetration Resistance: 450 Pa Ultimate Strength Pressure: N6/C3 | 03/02/2025 |
| AOLAND | AD150 | Glass Louver Window | Non-Thermal break Aluminium Glass Louver Window - 705mm(W) x 1550mm(H) x 150mm(T) – Opening: 560mm(W) x 1439mm(H) with AS/NZS 2208:1996, AS 2208:2023 & AS 4666:2012 Glazing Model: 6063-T5 | Water Penetration Resistance: 200 Pa | 03/02/2025 |
| AOLAND | AD418 | Sliding Door | Non-Thermal Break Aluminium Sliding Door - 2400mm(W) x 2400mm(H) x 100mm(T) - Operable Sash 1184mm(W) x 2310mm(H) - Fixed Sash 1184mm(W) x 2310mm(H) with AS/NZS 2208:1996, AS 2208:2023 & AS 4666:2012 Glazing Model: AD 245 | Serviceability Limit Pressure: 1200 Pa Ultimate Strength Pressure: 3000 Pa Water Penetration Resistance: 200 Pa Ultimate Strength Pressure: N5/C2 | 03/02/2025 |

End of Record

Certificate No: PC10103

Originally Certified: 03/02/2025

Updated: 03/02/2025

Expires: 03/02/2030

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>

