



CMI ProdCert
PC10088

CERTIFICATE OF CONFORMITY

This is to certify that

Spill Crew Australia

Is certified to manufacture products to:

AS 4775:2007 Emergency Eyewash and Shower Equipment

Certificate Holder

Spill Crew Australia

202 Settlement Road, Thomastown
Victoria 3074 Australia
ACN: 30155668152
W: <https://www.spillcrew.com.au/>
Ph: 1300 485 000

Product Description

Emergency Eyewash and Shower Equipment

Product Purpose or Use

Emergency Eyewash and Shower Equipment

Subject to the following Conditions & Limitations:

Nil

Certification Body



CMI Certification Pty Ltd

ABN: 81 663 250 815
JAS-ANZ Accreditation No.
Z4450210AK
PO Box 273, Palmwoods Qld 4555,
Australia
Ph: +61 7 5445 2199
E: office@cmicert.com.au
W: <https://cmicert.com.au/>

Certificate No: PC10088

Originally Certified: 17/05/2024

Updated: 12/03/2025

Expires: 17/05/2029

Talissa Ireland
CMI Certification Pty Ltd



- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>





CMI ProdCert
PC10088

CERTIFICATE OF CONFORMITY

This is to certify that

Spill Crew Australia

Is certified to manufacture products to:

AS 4775:2007 Emergency Eyewash and Shower Equipment

Brand	Model	Description	Requirements	Date Endorsed
Spill Crew	SCES-EW3	Eye Wash with Bowl, Hand Activated, Bullhorn, 2 Small Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 850mm, c/w SMS Nut, Baseplate & 38mm Waste Outlet, Waste Receptor (T), Activation Manifold c/w Valves & Handle, 1/2"BSP compression inlet with olive	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 11 L/min	17/05/2024
Spill Crew	SCES-EW4	Eye Wash with Bowl & Foot Treadle, Hand & Foot Activated, Bullhorn, 2 Small Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 850mm, c/w SMS Nut, Baseplate & 38mm Waste Outlet, Waste Receptor (T), Activation Manifold c/w Valves & Handle, 1/2"BSP compression inlet with olive	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 11 L/min	17/05/2024
Spill Crew	SCES-EF3	Eye/Face Wash with Bowl, Hand Activated, Bullhorn, 2 Large Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 850mm, c/w SMS Nut, Baseplate & 38mm Waste Outlet, Waste Receptor (T), Activation Manifold c/w Valves & Handle, 1/2"BSP compression inlet with olive	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 18 L/min	17/05/2024
Spill Crew	SCES-EF4	Eye/Face Wash with Bowl & Foot Treadle, Hand & Foot Activated, Bullhorn, 2 Large Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 850mm, c/w SMS Nut, Baseplate & 38mm Waste Outlet, Waste Receptor (T), Activation Manifold c/w Valves & Handle, 1/2"BSP compression inlet with olive	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 18 L/min	17/05/2024

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>

Spill Crew	SCES-DS1	Deluge Shower, Hand Activation, Stanchion, 1150mm c/w SMS Male, Baseplate & 25mm BSP inlet	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 76 L/min	17/05/2024
Spill Crew	SCES-DSW	Deluge Shower, Hand Activation, Wall Mount & 25mm BSP inlet	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 76 L/min	17/05/2024
Spill Crew	SCES-CE1	Combination Eyewash with Shower, Flow Regulator, Activation Valve & Pull Handle, Bullhorn, 2 Small Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 87 L/min	17/05/2024
Spill Crew	SCES-CE2	Combination Eyewash with Shower & Foot Treadle, Hand & Foot Activated, Flow Regulator, Activation Valve & Pull Handle, Bullhorn, 2 Small Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 87 L/min	17/05/2024
Spill Crew	SCES-CE3	Combination Eyewash with Shower & Bowl, Hand Activated, Flow Regulator, Activation Valve & Pull Handle, Bullhorn, 2 Small Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 87 L/min	17/05/2024
Spill Crew	SCES-CE4	Combination Eyewash with Shower & Bowl & Foot Treadle, Hand & Foot Activated, Flow Regulator, Activation Valve & Pull Handle, Bullhorn, 2 Small Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 87 L/min	17/05/2024
Spill Crew	SCES-CF1	Combination Eye/Face Wash with Shower, Flow Regulator, Activation Valve & Pull Handle, 2 Large Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 94 L/min	17/05/2024

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>

Spill Crew	SCES-CF2	Combination Eye/Face Wash with Shower & Foot Treadle, Hand & Foot Activated, Flow Regulator, Activation Valve & Pull Handle, 2 Large Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 94 L/min	17/05/2024
Spill Crew	SCES-CF3	Combination Eye/Face Wash with Shower & Bowl, Hand Activated, Flow Regulator, Activation Valve & Pull Handle, 2 Large Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 94 L/min	17/05/2024
Spill Crew	SCES-CF4	Combination Eye/Face Wash with Shower & Bowl & Foot Treadle, Hand & Foot Activated, Flow Regulator, Activation Valve & Pull Handle, 2 Large Spray Heads, 2 Flow Regulators, 2 Filters, Stanchion, 1150mm c/w SMS Male, Baseplate, 38mm Waste Outlet & 25mm BSP inlet, Drain Arm c/w SMS Nut & Waste Receptor (T)	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 94 L/min	17/05/2024
Spill Crew	SCES-EW3W	Eye Wash with Bowl, Hand Activated, Bullhorn, Wall Mount, 2 Small Spray Heads, 2 Flow Regulators, 2 Filters, c/w SMS Nut, 32mm Waste Outlet, Waste Receptor (T), Activation Manifold c/w Valves & Handle, 1/2"BSP compression inlet with olive	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 11 L/min	12/03/2025
Spill Crew	SCES-EF3W	Eye/Face Wash with Bowl, Hand Activated, Bullhorn, Wall Mount, 2 Large Spray Heads, 2 Flow Regulators, 2 Filters, c/w SMS Nut, 32mm Waste Outlet, Waste Receptor (T), Activation Manifold c/w Valves & Handle, 1/2"BSP compression inlet with olive	Water Inlet Pressure: 210kPa to 500kPa Design Flow Rate: 18 L/min	12/03/2025

End of Record

Certificate No: PC10088

Originally Certified: 17/05/2024

Updated: 12/03/2025

Expires: 17/05/2029

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>