



Certificate of Conformity

THIS CERTIFICATE IS GRANTED TO

Stanley Electric Co., Ltd

Yokohama Technical Center, 2-14-1 Edanishi, Aobaku,

Yokohama, Kanagawa 2250014 Japan

W: <https://www.stanley.co.jp/>

Subject to the following conditions and limitations:

1. The Approved Certifier grants the right to use or arrange the use of the WaterMark as shown in the top left corner only in respect of the Products described and detailed on the Product Schedule following which are produced by the Approved User and which comply with the appropriate Applicable Specification referenced below and as amended from time to time. The Licence is granted subject to the rules governing the use of the WaterMark and the terms and conditions for certification. The WaterMark Licensee covenants to comply with all the Rules, technical reference documents and terms and conditions of the WaterMark Certification Scheme.
2. The Certified products must be installed in accordance with the current version of the Plumbing Code of Australia.
3. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.
4. Information contained herein or related hereto is intended only for evaluation by technically skilled persons, with any use thereof to be at their independent discretion and risk. Such information is believed to be reliable, but CMI Certification Pty Ltd (CMI) shall have no responsibility or liability for results obtained or damages resulting from such use. CMI grants no license under, and shall have no responsibility or liability for infringement of, any patent or other proprietary right. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate holder.

Talissa Ireland

CMI Certification Pty Ltd

PO Box 273, Palmwoods, Qld 4555, Australia

ABN: 81 663 250 815

T: + 61 7 5445 2199

W: <https://cmicert.com.au>

E: office@cmicert.com.au



080093	20/12/2024	20/12/2024	19/12/2029	AS 3497:2021 Drinking water treatment systems – Design and performance requirements
CERTIFICATE NUMBER	INITIAL CERTIFICATION DATE	CURRENT CERTIFICATION DATE	CERTIFICATION EXPIRY DATE	APPLICABLE STANDARD/SPECIFICATION

This Certificate is issued by a JAS-ANZ accredited certification body. The Scheme Owner, Administering Body and Accreditation Body do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The Scheme Owner disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate.

The WaterMark is a registered certification trademark of the Scheme Owner (ABN 74 599 608 295). The rules of the WaterMark Certification Scheme are available from the ABCB website www.abcb.gov.au





Schedule To

Stanley Electric Co., Ltd



APPLICABLE
STANDARD/SPECIFICATION
AS 3497:2021 Drinking water treatment systems – Design and performance
requirements

Brand Name	Model Name	Model Identification	Product Description	Scope of Use	Lead Free* Yes/No**/Not Applicable	Date Endorsed
Stanley Electric	ULR18C	87048268	UV-LED Water Treatment System – Category I - Bacteriostatic incorporating: ULR6D UV-LED Reactor – 19305252 Flow Sensor - FL-408W-JST-PS – 73278139 Fittings – PI451614CS – 62035390 Power Supply – UVI/K0038A - 74016758	Water Temperature Range: 4°C to 25°C Ambient Temperature Range: 4°C to 40°C Flow Rate Range: 2L/min to 5.6L/min Water Pressure Range: 0.1MPa to 0.69MPa	N/A	20/12/2024

*Lead Free compliance in accordance with NCC 2022 - Volume Three – Plumbing Code of Australia - A5G4(2)(b)

End of Record