



Certificate of Conformity

THIS CERTIFICATE IS GRANTED TO

UFB GLOBAL STANDARDS PTY LTD

41209, 5 Harbourside Court,
Biggera Waters, QLD 4216, Australia

ABN: 76 680 228 835

W: <https://ufbglobal.com.au>

E: sales@ufbglobal.com.au

Subject to the following conditions and limitations:

1. The Approved Certifier grants the right to use or arrange the use of the WaterMark as shown in the top left corner only in respect of the Products described and detailed on the Product Schedule following which are produced by the Approved User and which comply with the appropriate Applicable Specification referenced below and as amended from time to time. The Licence is granted subject to the rules governing the use of the WaterMark and the terms and conditions for certification. The WaterMark Licensee covenants to comply with all the Rules, technical reference documents and terms and conditions of the WaterMark Certification Scheme.
2. The Certified products must be installed in accordance with the current version of the Plumbing Code of Australia.
3. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.
4. Information contained herein or related hereto is intended only for evaluation by technically skilled persons, with any use thereof to be at their independent discretion and risk. Such information is believed to be reliable, but CMI Certification Pty Ltd (CMI) shall have no responsibility or liability for results obtained or damages resulting from such use. CMI grants no license under, and shall have no responsibility or liability for infringement of, any patent or other proprietary right. Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate holder.

Talissa Ireland

CMI Certification Pty Ltd

PO Box 273, Palmwoods, Qld 4555, Australia

ABN: 81 663 250 815

T: + 61 7 5445 2199

W: www.cmicert.com.au

E: office@cmicert.com.au



080098	01/01/2025	01/04/2025	31/03/2030	AS 3497:2021 Drinking Water Treatment Systems
--------	------------	------------	------------	---

CERTIFICATE NUMBER	INITIAL CERTIFICATION DATE	CURRENT CERTIFICATION DATE	CERTIFICATION EXPIRY DATE	APPLICABLE STANDARD/SPECIFICATION
-----------------------	-------------------------------	-------------------------------	------------------------------	--------------------------------------

This Certificate is issued by a JAS-ANZ accredited certification body. The Scheme Owner, Administering Body and Accreditation Body do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The Scheme Owner disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate.

The WaterMark is a registered certification trademark of the Scheme Owner (ABN 74 599 608 295). The rules of the WaterMark Certification Scheme are available from the ABCB website www.abcb.gov.au





Schedule To

UFB GLOBAL STANDARDS PTY LTD



APPLICABLE
STANDARD/SPECIFICATION

AS 3497:2021 Drinking Water Treatment Systems

Brand Name	Model Name	Model Identification	Product Description	Scope of Use	Lead Free* Yes/No**/Not Applicable	Date Endorsed
UFB Global Standards	UFB DUAL 20A	WF-20C3WD	Inline Water Treatment Device creating Ultra Fine Bubbles (UFB) – Category VI – DR Brass with 20A Exit/Entrance 3/4" male thread connections.	Category VI Use with Tap Water Supply Water Temp: 5°C - 80°C Water Pressure: 0.05MPa - 1.7MPa Flow Rate: 6L/min - 60L/min	Yes	01/04/2025
UFB Global Standards	UFB DUAL 25A	WF-25C5WD	Inline Water Treatment Device creating Ultra Fine Bubbles (UFB) – Category VI – DR Brass with 25A Exit/Entrance Rc1 connections.	Category VI Water Temp: 5°C - 80°C Water Pressure: 0.05MPa - 1.7MPa Flow Rate: 6L/min - 100L/min	Yes	01/04/2025

*Lead Free compliance in accordance with NCC 2022 - Volume Three – Plumbing Code of Australia - A5G4(2)(b)

End of Record