



CMI ProdCert
PC10131

CERTIFICATE OF CONFORMITY

This is to certify that

Xuzhou Longsheng Wood Products Co Ltd

Is certified to manufacture products to:

AS/NZS 4357.0:2022 Structural laminated veneer lumber, Part 0: Specifications

Certificate Holder

**Xuzhou Longsheng
Wood Products Co Ltd**
No. 210-1, Jianyi Building, South Area of
Kuiyuan New Residence, Tanan,
Quanshan District, Xuzhou,
Jiangsu Province 27600 China

Product Description

Structural Laminated Veneer Lumber

Product Purpose or Use

Structural Laminated Veneer Lumber

Subject to the following Conditions & Limitations:

Nil

Certificate No: PC10131

Originally Certified: 13/08/2025

Updated: 07/05/2026

Expires: 13/08/2030

Talissa Ireland
CMI Certification Pty Ltd

Certification Body



CMI Certification Pty Ltd
ABN: 81 663 250 815
JAS-ANZ Accreditation No.
Z4450210AK
PO Box 273, Palmwoods Qld 4555,
Australia
Ph: +61 7 5445 2199
E: office@cmicert.com.au
W: <https://cmicert.com.au/>



- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>



CMI ProdCert



WWW.JASANZ.ORG/REGISTER

CERTIFICATE OF CONFORMITY

This is to certify that

Xuzhou Longsheng Wood Products Co Ltd

Is certified to manufacture products to:

AS/NZS 4357.0:2022 Structural laminated veneer lumber, Part 0: Specifications



Wood Species: Mixed Wood Species Radiata Pine & Masson Pine – Plies: ≥ 18 – Thickness: ≥ 35mm

Brand	Model	Use	F-Grade	Bond Type	Adhesive	Treatment	Emission Class	On Edge E [MPa]	On Edge f'_b [MPa]	On Edge f'_s [MPa]	On Edge f'_ρ [MPa]	On Edge f'_{sj} [MPa]	On Flat E [MPa]	On Flat f'_b [MPa]	On Flat f'_s [MPa]	On Flat f'_ρ [MPa]	On Flat f'_{sj} [MPa]	Axial f'_t [MPa]	Axial f'_c [MPa]	Date Endorsed
Longsheng	F8	General Structural Use	F8	A	Phenolic Formaldehyde Resin	Bifenthrin H2 S Glueline Treatment	Super E ₀	1020	51.51	3.91	10.44	-	9850	55.28	4.15	6.28	-	33.44	39.09	13/08/2025

Wood Species: Mixed Wood Species Radiata Pine & Masson Pine – Plies: ≥ 23 – Thickness: ≥ 45mm

Brand	Model	Use	F-Grade	Bond Type	Adhesive	Treatment	Emission Class	On Edge E [MPa]	On Edge f'_b [MPa]	On Edge f'_s [MPa]	On Edge f'_ρ [MPa]	On Edge f'_{sj} [MPa]	On Flat E [MPa]	On Flat f'_b [MPa]	On Flat f'_s [MPa]	On Flat f'_ρ [MPa]	On Flat f'_{sj} [MPa]	Axial f'_t [MPa]	Axial f'_c [MPa]	Date Endorsed
Longsheng	F11	General Structural Use	F11	A	Phenolic Formaldehyde Resin	Bifenthrin H2 S Glueline Treatment	Super E ₀	10900	59.16	4.48	10.40	-	10800	55.95	3.89	7.62	-	31.37	47.48	13/08/2025

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>



Wood Species: Mixed Wood Species Radiata Pine & Masson Pine – Plies: ≥ 32 – Thickness: ≥ 63mm

Brand	Model	Use	F-Grade	Bond Type	Adhesive	Treatment	Emission Class	On Edge E [MPa]	On Edge f'_b [MPa]	On Edge f'_s [MPa]	On Edge f'_ρ [MPa]	On Edge f'_{sj} [MPa]	On Flat E [MPa]	On Flat f'_b [MPa]	On Flat f'_s [MPa]	On Flat f'_ρ [MPa]	On Flat f'_{sj} [MPa]	Axial f'_t [MPa]	Axial f'_c [MPa]	Date Endorsed
Longsheng	F11	General Structural Use	F11	A	Phenolic Formaldehyde Resin	Bifenthrin H2 S Glueline Treatment	Super E ₀	10750	51.27	4.43	9.57	-	11150	49.06	3.93	6.86	-	35.17	44.61	13/08/2025

Wood Species: Wood Species Masson Pine – Plies: ≥ 15 – Thickness: ≥ 35mm

Brand	Model	Use	F-Grade	Bond Type	Adhesive	Treatment	Emission Class	On Edge E [MPa]	On Edge f'_b [MPa]	On Edge f'_s [MPa]	On Edge f'_ρ [MPa]	On Edge f'_{sj} [MPa]	On Flat E [MPa]	On Flat f'_b [MPa]	On Flat f'_s [MPa]	On Flat f'_ρ [MPa]	On Flat f'_{sj} [MPa]	Axial f'_t [MPa]	Axial f'_c [MPa]	Date Endorsed
Longsheng	F8	General Structural Use	F11	A	Phenolic Formaldehyde Resin	Bifenthrin H2 S Glueline Treatment	Super E ₀	10500	40.51	4.15	14.12	-	10900	43.63	3.95	6.46	-	26.45	38.90	07/05/2026
Longsheng	F11	General Structural Use	F11	A	Phenolic Formaldehyde Resin	Bifenthrin H2 S Glueline Treatment	Super E ₀	10500	40.51	4.15	14.12	-	10900	43.63	3.95	6.46	-	26.45	38.90	07/05/2026

End of Record

Certificate No: PC10131

Originally Certified: 13/08/2025

Updated: 07/05/2026

Expires: 13/08/2030

- The Certificate is issued to and relates to the certification of the described product(s) to the requirements of the described relevant Standard(s) and is subject to the conditions and limitations as described hereupon. CMI Certification Pty Ltd (CMI) is an Accredited Product Certification Body and undertakes certification in accordance with ISO/IEC 17065. The CMI ProdCert Scheme is an ISO/IEC 17067 Type 5 Scheme applicable to products seeking to show conformity to a particular Standard. This certification is to be read, considered and used as a whole document and may only be reproduced in its entirety. For further information contact the certificate holder. Nothing in this certificate should be construed as a warranty or guarantee by CMI, and the only applicable warranties or guarantees will be those provided by the Certificate Holder. CMI by granting this certification shall have no responsibility or liability for infringement of, any patent or other proprietary right.
- It is advised to check that this Certificate is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the CMI website <https://register.cmicert.com.au/>

